



**STATE OF DELAWARE  
EXECUTIVE DEPARTMENT  
OFFICE OF STATE PLANNING COORDINATION**

February 21, 2011

Charlie Barnett  
Morris & Ritchie Associates, Inc.  
18 Boulden Circle, Ste. 36  
New Castle, DE 19720

RE: PLUS review – 2011-01-05; Double Eagle Farms

Dear Barnett:

Thank you for meeting with State agency planners on January 26, 2011 to discuss the proposed plans for Double Eagle Farms project to be located on Townsend Road, between Inland Bay Road and Harmon Hill Road.

According to the information received, you are seeking a rezoning of the development from AR-1 to RPC on 35.27 acres for a subdivision of 110 residential lots.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State and local regulations regarding this property. We also note that as Sussex County is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the County.**

**Strategies for State Policies and Spending**

This parcel is located within a Level 4 area according to the Strategies for State Policies and Spending. This proposal is located in Investment Level 4 according to the Strategies for State Policies and Spending, and is in the low density area according to the Sussex County Comprehensive Plan. The comments in this letter are technical, and are not intended to suggest that the State supports this development proposal. This letter does not in any way suggest or imply that you may receive or may be entitled to permits or other approvals necessary to construct the development you indicate or any subdivision thereof on these lands.

This project represents a major land development that will result in 110 residential units in an Investment Level 4 area according to the *2004 Strategies for State Policies and Spending*. Investment Level 4 indicates where State investments will support agricultural preservation, natural resource protection, and the continuation of the rural nature of these areas. New development activities and suburban development are not supported in Investment Level 4. These areas are comprised of prime agricultural lands and environmentally sensitive wetlands and wildlife habitats, which should be, and in many cases have been preserved.

From a fiscal responsibility perspective, development of this site is likewise inappropriate. The cost of providing services to development in rural areas is an inefficient and wasteful use of the State's fiscal resources. The project as proposed is likely to bring more than 750 new residents to an area where the State has no plans to invest in infrastructure upgrades or additional services. These residents will need access to such services and infrastructure as schools, police, and transportation. To provide some examples, the State government funds 100 percent of school transportation and paratransit services, up to 80% of school construction costs, and the cost of police protection in the unincorporated portion of Sussex County where this development is proposed. Over the longer term, the unseen negative ramifications of this development will become even more evident as the community matures and the cost of maintaining infrastructure and providing services increases.

Because the development is inconsistent with the *Strategies for State Policies and Spending*, the State is opposed to this proposed subdivision.

### **Code Requirements/Agency Permitting Requirements**

#### **State Historic Preservation Office – Contact Terrence Burns 736-7404**

- The Division of Historical & Cultural Affairs does not support, nor approve of the rezoning, or a proposed development or construction project of any kind in a Level 4 Area. In Delaware, there is a strong agricultural and rural heritage historically, and usually there are known or potential cultural or historic resources in these areas, such as an archaeological or architectural site. Furthermore, intruding on these areas may affect the historic context as well as the cultural or historic resources historically associated with Delaware's rural heritage, such as potential historic or prehistoric-period archaeological sites, which have not been found or are not yet studied, but may contain important information about Delaware's history.

Since this parcel (property) is located in a rural area, there is a high probability for prehistoric and historic archaeological sites, as well as the forested area, which is nearby. With this in mind, it is important that the developer be aware of the Delaware Unmarked Human Remains Act of 1987, outlined in Chapter 54 of Title 7 of the Delaware Code, which pertains to the discovery and disposition of such remains, because the unexpected discovery of unmarked human remains during construction can result in significant delays while the process is carried out.

Therefore, prior to any demolition or ground-disturbing activities, the developer should consider hiring an archaeological consultant to examine the parcel for archaeological sites, such as a cemetery or unmarked human remains. Furthermore, if there is any federal involvement with the project, in the form of licenses, permits, or funds, the federal agency, often through its client, is responsible for complying with Section 106 of the National Historic Preservation Act (36 CFR 800) and must consider their project's effects on any known or potential culture or historic resources.

Department of Transportation – Contact Bill Brockenbrough 760-2109

- Because the subject land is located in a Level 4 area, development of it as proposed is inconsistent with the *Strategies for State Policies and Spending*. As part of our commitment to support the *Strategies*, DeIDOT refrains from participating in the cost of any road improvements needed to support this development and is opposed to any road improvements that will substantially increase the transportation system capacity in this area. DeIDOT will only support taking the steps necessary to preserve the existing transportation infrastructure and make whatever safety and drainage related improvements are deemed appropriate and necessary.
- The site access and subdivision streets must be designed in accordance with DeIDOT's Standards and Regulations for Subdivision Streets and State Highway Access. This manual is available on-line at [http://www.deldot.gov/information/pubs\\_forms/manuals/subdivisions/pdf/Subdivision Manual Revision 1 proposed 060110.pdf](http://www.deldot.gov/information/pubs_forms/manuals/subdivisions/pdf/Subdivision_Manual_Revision_1_proposed_060110.pdf). Please note that the previous entrance approval was based on an older set of regulations. Because the number of dwelling units is being increased, that approval will not apply to this new plan and a significant redesign of the site access may be necessary.
- As proposed, the subject development would meet DeIDOT's volume warrants for a traffic impact study (TIS), as contained in Section 2.3.1 of the Standards and Regulations. However, as discussed in Section 2.3.2, they would also be eligible to pay the Area-Wide Study Fee in lieu of doing that TIS. The fee would be equal to \$10 per daily trip, or \$9,900 based on the plan presented, and would be due at the same time as the initial stage fee, which is paid when plans are submitted to obtain a "Letter of No Objection." The fee is not an impact fee and payment of it does not exempt the developer from having to make off-site road improvements or from the need to provide a Traffic Operational Analysis if necessary to aid us in determining those improvements. In accordance with Section 3.10.2 of the Standards and Regulations, all required off-site improvements, and the schedule for their construction, must be specified by notes on the record plan.
- As per Section 3.10.2 of the Standards and Regulations, as part of the entrance improvements, we anticipate requiring the applicant to improve Townsend Road (Sussex

Road 303) to more nearly meet DelDOT local road standards (11-foot travel lanes and 5-foot shoulders) from Harmony Cemetery Road (Sussex Road 306) to the east end of their site frontage. These improvements would also include a 10-foot wide multi-use path in a 15-foot wide permanent easement along one or both sides of Townsend Road to connect to the planned improvements to be done by the developers of Pelican Point. Presently those improvements are planned only along the south side of Townsend Road.

- DelDOT anticipates that Sussex County will require a “Letter of No Objection” from the Department for this project. Per Section 3.4 of the Standards and Regulations, the developer must submit **three (3) signed and sealed** copies of the **record plan**, with an Initial Stage Fee Calculation Form and the Initial Stage Fee. The review fee will be based on the number of lots within the subdivision. Please make all submissions to Mr. John Fiori, Subdivision Manager. Mr. Fiori may be reached at (302) 760-2260.
- As specified in Section 4.1 of the Standards and Regulations, when the entrance construction plans are submitted for review, the developer must submit **two (2) copies** of the construction plans, one copy of the record plan, an Initial Stage Fee Calculation Form, a Construction Stage Fee Calculation Form, a Construction Stage Review Fee, an application for highway entrance permit and a signed and sealed commercial entrance design checklist for review and approval. Please make all submissions to Mr. John Fiori, Subdivision Manager.

Department of Natural Resources and Environmental Control – Contact Kevin Coyle 739-9071

#### **Investment Level 4 Policy Statement**

- This project is proposed for an Investment Level 4 area as defined by the Strategies for State Policies and Spending and is also located outside of a designated growth area in the relevant municipal and County certified comprehensive plans. According to the Strategies, this project is inappropriate in this location. In Investment Level 4 areas, the State’s investments and policies, from DNREC’s perspective, should retain the rural landscape and preserve open spaces and farmlands. Open space investments should emphasize the protection of critical natural habitat and wildlife to support a diversity of species, and the protection of present and future water supplies. Open space investments should also provide for recreational activities, while helping to define growth areas. Additional state investments in water and wastewater systems should be limited to existing or imminent public health, safety or environmental risks only, with little provision for additional capacity to accommodate further development.

With continued development in Investment Level 4 areas, the State will have a difficult, if not impossible, time attaining water quality (e.g., TMDLs) and air quality (e.g., non-attainment areas for ozone and fine particulates) goals. Present and future investments in green infrastructure will be threatened. DNREC strongly supports new development in and around existing towns and municipalities and in areas designated as growth zones in

certified Comprehensive Plans. We encourage the use of transfer of development rights where this growth management tool is available.

This particular development certainly compromises the integrity of the State Strategies and the preservation goals inherent in many of DNREC's programs. While mitigating measures such as conservation design, central wastewater systems instead of individual on-site septic systems, and other best management practices may help mitigate impacts from this project, not doing the project at all is the best avenue for avoiding negative impacts. As such, this project will receive no financial, technical or other support of any kind from DNREC. Any required permits or other authorizations for this project shall be considered in light of the project's conflict with our State growth strategies.

## **Wetlands**

- The applicant is responsible for determining whether any State-regulated wetlands (regulated pursuant to 7 Del.C. Chapter 66 and the Wetlands Regulations) are present on the property. This determination can only be made by contacting the Division of Water Resources' Wetlands and Subaqueous Lands Section at 302/739-9943 and consulting the State's official wetland regulatory maps, which depict the extent of State jurisdiction. The area regulated by State law may be very different from the area under federal authority. No activity may take place in State-regulated wetlands without a permit from DNREC's Wetlands Section.

In addition, most perennial streams and ditches and many intermittent streams and ditches are regulated pursuant to the Subaqueous Lands Act (7 Del.C. Chapter 72) and the Regulations Governing the Use of Subaqueous Lands. Ponds which are connected to other waters are also regulated, while isolated ponds are not. Any work in regulated streams, ditches or ponds requires a permit from the Wetlands and Subaqueous Lands Section. An on-site jurisdictional determination is recommended in order to determine whether any regulated watercourses exist on the property. Please contact the Wetlands and Subaqueous Lands Section at 302/739-9943 to schedule an on-site visit. Such appointments can usually be scheduled within 2 to 3 weeks.

When designing a project on a site with regulated watercourses, any extensive piping, filling or burying of streams or ditches in excess of the minimum needed for road crossings should be avoided. Where road crossings are necessary, bridge spans which avoid significant impacts to stream banks and channels should be used wherever possible. Where placement of culverts is unavoidable, culvert designs which utilize multiple barrels at different elevations to preserve a low flow channel are usually preferred. Contact the Wetlands and Subaqueous Lands Section for further information regarding preferred designs.

## TMDLs

- The project is located in the greater Inland Bays drainage - specifically within the area designated as the “low nutrient reduction zone” of the Indian River Bay watershed. In this portion of the watershed, specific Total Maximum Daily Load (TMDL) pollutant reduction targets have been developed by the State of Delaware (under the auspices of Section 303(d) of the 1972 Federal Clean Water Act) for nutrients (e.g., nitrogen, phosphorus), and bacteria. A TMDL is the maximum level of pollution allowed for a given pollutant below which a “water quality limited water body” can assimilate and still meet State water quality standards (e.g., dissolved oxygen, nutrients, and bacteria; *State of Delaware Surface Water Quality Standards, as amended July 11, 2004*) to the extent necessary to support use goals such as, swimming, fishing, drinking water and shell fish harvesting. The TMDL for the Low Reduction zone of the Inland Bays watershed calls for a 40 percent reduction in nitrogen and phosphorus from baseline conditions. The TMDL also calls for a 40 percent reduction in bacteria from baseline conditions.
- A nutrient management plan is required under the *Delaware Nutrient Management law (3 Del. Chapter 22)* for all persons or entities who apply nutrients to lands or areas of open space in excess of 10 acres. This project’s open space may exceed this 10-acre threshold. Please contact the Delaware Nutrient Management Program at 739-4811 for further information concerning compliance requirements or view the following web link for additional information: <http://dda.delaware.gov/nutrients/index.shtml>
- The adopted Inland Bays Pollution Control Strategy regulation was published in the Delaware Register of Regulations on November 11, 2008 and is now an enforceable regulatory directive. A Pollution Control Strategy (PCS) is an implementation strategy that identifies the actions necessary (regulatory and nonregulatory) to systematically reduce the pollutant loading to a given water body, and meet the TMDL reduction requirements specified for that water body. These regulations can be reviewed at <http://regulations.delaware.gov/documents/November2008c.pdf> and background information, guidance documents, and mapping tools can be retrieved from [http://www.dnrec.state.de.us/water2000/Sections/Watershed/ws/ib\\_pcs.htm](http://www.dnrec.state.de.us/water2000/Sections/Watershed/ws/ib_pcs.htm). The regulations address establishing a buffer zone sediment and stormwater controls for new development projects, and additional measures and standards for onsite wastewater treatment and disposal systems. Additionally, a map of water features identifies the specific primary and secondary water features that require buffers; this can be reviewed at <http://maps.dnrec.delaware.gov/inlandbayspcs93/>.
- The regulations require that buffers of a specified width be established for State-regulated wetlands, tidal waters, primary and secondary water features. The width may be reduced when combined with advanced sediment and stormwater controls and upon the creation of a development-wide nutrient management plan. Buffers must be placed in common open space and be clearly demarcated, designated and recorded on final plans or plat.

Buffers must be maintained in perpetuity and must have boundary signs or markers or distinctive vegetation identifying the upland edge of the buffer.

- The regulations also require that permanent sediment and stormwater management plans be designed and implemented to include design criteria to further reduce nutrient contributions. Compliance with this provision can be through any of the options below.
- For properties with primary and secondary water features:
  1. Implement standard width buffers
  2. Implement reduced buffer widths in conjunction with the creation and use of a development-wide nutrient management plan (NMP), and the implementation of at least one advanced stormwater treatment control method.
- For properties without primary or secondary water features, or for those properties with primary and secondary water features that employ a reduced-width buffer (in addition to the required NMP), select from at least one of the following advanced stormwater treatment control methods:
  1. Reduce nutrients by the TMDL percentage
  2. Reduce nutrients to irreducible concentration levels
  3. Implement three practices within a treatment train
  4. Establish 30% of the project parcels as forest in common open space (See appendix L in the PCS regulations for planting requirements).
- The applicant should also remember that a nutrient management plan (NMP) is also required when electing to pursue a reduced buffer width for their project. An NMP is also required for those properties without primary or secondary water features. The Nutrient Management Program link can be retrieved at <http://dda.delaware.gov/nutrients/index.shtml>

## **Water Supply**

- The information provided indicates that Artesian Water Company will provide water to the proposed project through a public water system. Our files reflect that Artesian Water Company does not currently hold a certificate of public convenience and necessity (CPCN) to provide public water in these areas. They will need to file an application for a CPCN with the Public Service Commission, if they have not done so already. Information on CPCN requirements and applications can be obtained by contacting the Public Service Commission at 302-736-7547. Should an on-site public well be needed, it must be located at least 150 feet from the outermost boundaries of the project and a minimum isolation distance of 150 feet is required between the well and any potential source of contamination, such as a septic tank and sewage disposal area. The Division of

Water Resources will consider applications for the construction of on-site wells provided the wells can be constructed and located in compliance with all requirements of the Regulations Governing the Construction and Use of Wells. A well construction permit must be obtained prior to constructing any wells.

- Should dewatering points be needed during any phase of construction, a dewatering well construction permit must be obtained from the Water Supply Section prior to construction of the well points. In addition, a water allocation permit will be needed if the pumping rate will exceed 50,000 gallons per day at any time during operation.
- All well permit applications must be prepared and signed by licensed water well contractors, and only licensed well drillers may construct the wells. Please factor in the necessary time for processing the well permit applications into the construction schedule. Dewatering well permit applications typically take approximately four weeks to process, which allows the necessary time for technical review and advertising.
- Potential Contamination Sources exist in the area, and any well permit applications will undergo a detailed review that may increase turnaround time and may require site specific conditions/recommendations. In this case, there is a Groundwater Management Zone associated with the Long Neck Sanitary Sewer District located within 1000 feet of the proposed project.

### **Sediment and Stormwater Program**

- A detailed sediment and stormwater plan will be required prior to any land disturbing activity taking place on the site. A project application meeting is required for this site. Contact the reviewing agency to schedule a project application meeting to discuss the sediment and erosion control and stormwater management components of the plan as soon as practicable. The site topography, soils mapping, pre and post development runoff, and proposed method(s) and location(s) of stormwater management should be brought to the meeting for discussion. The plan review and approval as well as construction inspection will be coordinated through Sussex Conservation District. Contact Jessica Watson at the Sussex Conservation District at (302) 856-2105 for details regarding submittal requirements and fees (Delaware Code, Title 7, Chapter 40; Delaware Regulations, Administrative Code, Title 7, 5101).

### **Hazardous Waste Sites**

- If it is determined by the Department that there was a release of a hazardous substance on the property in question and the Department requires remediation pursuant to the Hazardous Substance Cleanup Act, the provisions of 7 Del.C. Chapter 91, Delaware Hazardous Substance Cleanup Act and the Delaware *Regulations Governing Hazardous Substance Cleanup* shall be followed.”

**Air Quality**

- The applicant shall comply with all applicable Delaware air quality regulations. Please note that the following regulations in Table 1 – Potential Regulatory Requirements may apply:

<b>Table 1: Potential Regulatory Requirements</b>	
<b>Regulation</b>	<b>Requirements</b>
<b>7 DE Admin. Code 1106</b> - Particulate Emissions from Construction and Materials Handling	<ul style="list-style-type: none"> <li>• Use dust suppressants and measures to prevent transport of dust off-site from material stockpile, material movement and use of unpaved roads.</li> <li>• Use covers on trucks that transport material to and from site to prevent visible emissions.</li> </ul>
<b>7 DE Admin. Code 1113</b> – Open Burning	<ul style="list-style-type: none"> <li>• Prohibit open burns statewide during the Ozone Season from May 1-Sept. 30 each year.</li> <li>• Prohibit the burning of land clearing debris.</li> <li>• Prohibit the burning of trash or building materials/debris.</li> </ul>
<b>7 DE Admin. Code 1135</b> – Conformity of General Federal Actions to the State Implementation Plan	<ul style="list-style-type: none"> <li>• Require, for any “federal action,” a conformity determination for each pollutant where the total of direct and indirect emissions would equal or exceed any of the de minimus levels (See Section 3.2.1)</li> </ul>
<b>7 DE Admin. Code 1141</b> – Limiting Emissions of Volatile Organic Compounds from Consumer and Commercial Products	<ul style="list-style-type: none"> <li>• Use structural/ paint coatings that are low in Volatile Organic Compounds.</li> <li>• Use covers on paint containers when paint containers are not in use.</li> </ul>
<b>7 DE Admin. Code 1144</b> – Control of Stationary Generator Emissions	<ul style="list-style-type: none"> <li>• Ensure that emissions of nitrogen oxides (NO<sub>x</sub>), non-methane hydrocarbons (NMHC), particulate matter (PM), sulfur dioxide (SO<sub>2</sub>), carbon monoxide (CO), and carbon dioxide (CO<sub>2</sub>) from emergency</li> </ul>

	<p>generators meet the emissions limits established. (see section 3.2).</p> <ul style="list-style-type: none"> <li>• Maintain recordkeeping and reporting requirements.</li> </ul>
<p><b>7 DE Admin. Code 1145</b> – Excessive Idling of Heavy Duty Vehicles</p>	<ul style="list-style-type: none"> <li>• Restrict idling time for trucks and buses having a gross vehicle weight of over 8,500 pounds to no more than three minutes.</li> </ul>

For a complete listing of all Delaware applicable regulations, please look at our website: <http://www.awm.delaware.gov/AQM/Pages/AirRegulations.aspx>.

Delaware State Fire Marshall’s Office – Contact Duane Fox 739-4394

At the time of formal submittal, the applicant shall provide; completed application, fee, and three sets of plans depicting the following in accordance with the Delaware State Fire Prevention Regulation:

**Fire Protection Water Requirements**

- Where a water distribution system is proposed for single-family dwellings it shall be capable of delivering at least 500 gpm for 1-hour duration, at 20-psi residual pressure. Fire hydrants with 1000 feet spacing on centers are required.
- Where a water distribution system is proposed for townhouse type dwellings it shall be capable of delivering at least 1000 gpm for 1-hour duration, at 20-psi residual pressure. Fire hydrants with 800 feet spacing on centers are required.
- The infrastructure for fire protection water shall be provided, including the size of water mains.

**Accessibility**

- All premises, which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads, and fire lanes so that all buildings on the premises are accessible to fire apparatus. This means that the access roads to the subdivision from Townsend Road must be constructed so fire department apparatus may negotiate it. If a “center island” is placed at an entrance into the subdivision, it shall be arranged in such a manner that it will not adversely affect quick and unimpeded travel of fire apparatus into the subdivision.
- Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.

- Any dead end road more than 300 feet in length shall be provided with a turn-around or cul-de-sac arranged such that fire apparatus will be able to turn around by making not more than one backing maneuver. The minimum paved radius of the cul-de-sac shall be 38 feet. The dimensions of the cul-de-sac or turn-around shall be shown on the final plans. Also, please be advised that parking is prohibited in the cul-de-sac or turn around.
- The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.
- The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.

**Gas Piping and System Information:**

- Provide type of fuel proposed, and show locations of bulk containers on plan.

**Required Notes:**

- Provide a note on the final plans submitted for review to read “ All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations”
- Name of Water Supplier
- Proposed Use
- National Fire Protection Association (NFPA) Construction Type
- Townhouse 2-hr separation wall details shall be shown on site plans
- Maximum Height of Buildings (including number of stories)
- Provide Road Names, even for County Roads

**Delaware Department of Education – Contact John Marinucci 735-4199**

- The majority of this proposed development is within the Cape Henlopen School District boundaries, however, the South-Eastern corner of the development appears to be within the Indian River School District boundaries.

Department of Agriculture – Contact Scott Blaier 698-4529

- The proposed development is near two properties currently enrolled in the State's Agricultural Lands Preservation Program (N & M Burton Farm Agricultural District, (Parcel Numbers # 2.34-16.00-11.00 and 2.34-16.00-17.00). Therefore, the activities conducted on these preserved properties will be protected by the agricultural use protections outlined in Title 3, Del. C., Chapter 9. These protections effect adjoining developing properties. The 300 foot notification requirement affects **all new deeds** in a subdivision located in whole or part within 300 feet of an Agricultural District. Please take note of these restrictions as follows:

**§ 910. Agricultural use protections.**

(a) Normal agricultural uses and activities conducted in a lawful manner are preferred and priority uses and activities in Agricultural Preservation Districts. In order to establish and maintain a preference and priority for such normal agricultural uses and activities and avert and negate complaints arising from normal noise, dust, manure and other odors, the use of agricultural chemicals and nighttime farm operations, land use adjacent to Agricultural Preservation Districts shall be subject to the following restrictions:

(1) For any new subdivision development located in whole or in part within 300 feet of the boundary of an Agricultural Preservation District, the owner of the development shall provide in the deed restrictions and any leases or agreements of sale for any residential lot or dwelling unit the following notice:

This property is located in the vicinity of an established Agricultural Preservation District in which normal agricultural uses and activities have been afforded the highest priority use status. It can be anticipated that such agricultural uses and activities may now or in the future involve noise, dust, manure and other odors, the use of agricultural chemicals and nighttime farm operations. The use and enjoyment of this property is expressly conditioned on acceptance of any annoyance or inconvenience which may result from such normal agricultural uses and activities."

(2) For any new subdivision development located in whole or in part within 50 feet of the boundary of an Agricultural Preservation District, no improvement requiring an occupancy approval shall be constructed within 50 feet of the boundary of the Agricultural Preservation District.

(b) Normal agricultural uses and activities conducted in accordance with good husbandry and best management practices in Agricultural Preservation Districts shall be deemed protected actions and not subject to any claim or complaint of nuisance, including any such claims under any existing or future county or

municipal code or ordinance. In the event a formal complaint alleging nuisance related to normal agricultural uses and activities is filed against an owner of lands located in an Agricultural Preservation District, such owner, upon prevailing in any such action, shall be entitled to recover reasonably incurred costs and expenses related to the defense of any such action, including reasonable attorney's fees (68 Del. Laws, c. 118, § 2.).

- In addition, if any wells are to be installed, Section 4.01(A)(2) of the Delaware Regulations Governing the Construction and Use of Wells will apply. This regulation states:

(2) For any parcel, lot, or subdivision created or recorded within fifty (50) feet of, or within the boundaries of, an Agricultural Lands Preservation District (as defined in Title 3, Del. C., Chapter 9); all wells constructed on such parcels shall be located a minimum of fifty (50) feet from any boundary of the Agricultural Lands Preservation District. This requirement does not apply to parcels recorded prior to the implementation date of these Regulations. However, it is recommended that all wells be placed the maximum distance possible from lands which are or have been used for the production of crops which have been subjected to the application of land applied federally regulated chemicals.

Section 1. Chapter 99, Code of Sussex Section 99-6 may also apply to this subdivision. The applicant should verify the applicability of this provision with Sussex County. This Section of the Code states:

G. Agricultural Use Protections.

- (1) Normal agricultural uses and activities conducted in a lawful manner are preferred. In order to establish and maintain a preference and priority for such normal agricultural uses and activities and avert and negate complaints arising from normal noise, dust, manure and other odors, the use of agricultural chemicals and nighttime farm operations, land uses adjacent to land used primarily for agricultural purposes shall be subject to the following restrictions:
  - (a) For any new subdivision development located in whole or in part within three hundred (300) feet of the boundary of land used primarily for agricultural purposes, the owner of the development shall provide in the deed restrictions and any leases or agreements of sale for any residential lot or dwelling unit the following notice:

“This property is located in the vicinity of land used primarily for agricultural purposes on which normal agricultural uses and activities have been afforded the highest priority use status. It can be anticipated that such agricultural uses and activities may now or in the future involve noise, dust, manure and other odors, the use of agricultural chemicals and nighttime farm operations. The use and enjoyment of this property is


expressly conditioned on acceptance of any annoyance or inconvenience which may result from such normal agricultural uses and activities.”

- (b) For any new subdivision development located in whole or in part within fifty (50) feet of the boundary of land used primarily for agricultural purposes no improvement requiring and occupancy approval for a residential type use shall be constructed within fifty (50) feet of the boundary of land used primarily for agricultural purposes

**Following receipt of this letter and upon filing of an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason therefore.**

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,

A handwritten signature in cursive script that reads "Constance C. Holland".

Constance C. Holland, AICP

Director, Office of State Planning Coordination

CC: Sussex County