



**STATE OF DELAWARE
EXECUTIVE DEPARTMENT
OFFICE OF STATE PLANNING COORDINATION**

September 23, 2015

Ms. Carol Ohm, P.E.
Apex Engineering, Inc.
27 W. Market St.
Newport, DE 19804

RE: PLUS review 2015-08-06; Stone Brook

Dear Ms. Ohm:

Thank you for meeting with State agency planners on August 26, 2015 to discuss the proposed plans for the Stone Brook project. According to the information received, you are seeking review of a subdivision for 7 residential units on 3.87 acres along Kennett Pike in New Castle County.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State and local regulations regarding this property. We also note that as New Castle County is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the County.**

Strategies for State Policies and Spending

This project is located in Investment Level 2 according to the *State Strategies for Policies and Spending*. Investment Level 2 reflects areas where growth is anticipated by local, county, and State plans in the near term future. State investments will support growth in these areas. We also, recommend that the Town review their comp plan to make sure this use is consistent with the Future Land Use portion of the plan.

Code Requirements/Agency Permitting Requirements

Department of Transportation – Contact Bill Brockenbrough 760-2109

- The proposed development's subdivision plan and subdivision street construction plan must be designed in accordance with DelDOT's Development Coordination Manual (formerly the Standards and Regulations for Subdivision Streets and State Highway

122 Martin Luther King Jr. Blvd. South – Haslet Armory · Third Floor · Dover, DE 19901
Phone (302)739-3090 · Fax (302) 739-5661 · www.stateplanning.delaware.gov

Access), which is available at

<http://www.deldot.gov/information/business/subdivisions/changes/index.shtml>.

- The proposed development would not meet DelDOT's volume-based criteria, found in Section 2.2.2.1 of the Manual, for recommending that a Traffic Impact Study (TIS) be required (500 vehicle trips per day or 50 vehicle trips per hour).
- Kennett Pike is classified as a Principal Arterial. Therefore, in accordance with Section 3.2.5 of the Manual, DelDOT will require the dedication of 40 feet of right-of-way, measured from the centerline of the road. The plan provided appears to meet this requirement. In accordance with the same section, DelDOT will also require the dedication of a 15-foot wide permanent easement beyond the right-of-way. The plan provided does not show such an easement.
- In accordance with Section 3.2.7.2 of the Manual, a 10-foot permanent easement shall be provided along each side of all reduced right-of-way street. The plan provided does not show this easement on the proposed turnaround features. Figure 5.1.5.2-a in the Manual shows the proper easement configuration.
- The proposed development is in an Investment Level 2 area with regard to the Strategies for State Policies and Spending. Therefore, in accordance with Section 3.5.4.2.A. of the Manual, DelDOT will require a sidewalk or Shared-Use Path in the aforementioned permanent easement along the site frontage on Kennett Pike.
- The proposed development has access to transit, specifically DART First State Route 10 (Delaware Avenue Kennett Pike). Therefore, in accordance with Section 3.5.4.2.B. of the Manual, DelDOT will require a sidewalk or Shared-Use Path along both sides of the internal streets.

Department of Natural Resources and Environmental Control – Contact Michael Tholstrup 735-3352

TMDLs.

- Total Maximum Daily Loads (TMDLs) for nitrogen, phosphorus, and bacteria have been promulgated through regulation in most of the State of Delaware's water bodies. A TMDL is the maximum level of pollution allowed for a given pollutant below which a "water quality limited waterbody" can assimilate and still meet State water quality standards (e.g., dissolved oxygen, nutrients, and bacteria; State of Delaware *Surface Water Quality Standards*, as amended July 11, 2004) to the extent necessary to support use goals such as, swimming, fishing, drinking water and shell fish harvesting. TMDLs are required by federal law (Section 303(d) of the 1972 Clean Water Act), and the states are charged with developing and implementing specific land use practices that support these goals. This project is located in the greater Piedmont drainage, specifically within the Brandywine sub-basin of the greater Christina River Basin. In the Christina River

Basin, post-development nitrogen and phosphorus loading must be capped at the pre-development or baseline loading rate (or a 0% post-construction increase in N & P in Delaware's portion of the Christina River Basin) to meet the required TMDL for each nutrient. Moreover, reductions in bacteria that range from 29% to 95% (High Flow) is also required (depending upon location). The specific required nutrient and bacterial requirements for the various stream segments in the Basin, and background information is outlined in the report entitled "*Christina River Basin High-Flow TMDL*" by the EPA. This report can be retrieved from the following weblink:

http://www.epa.gov/reg3wapd/tmdl/pa_tmdl/ChristinaMeetingTMDL/index.htm

- A nutrient management plan is required under the *Delaware Nutrient Management Law* (3 Del. Chapter 22) for all persons or entities who apply nutrients to lands or areas of open space in excess of 10 acres. According to the submitted PLUS application, this project's open space may exceed this 10-acre threshold. Please contact the Delaware Nutrient Management Program at (302) 739-4811 for further information concerning compliance requirements, or view the following web link:
<http://dda.delaware.gov/nutrients/index.shtml>

Water Supply.

- The project information sheets state water will be provided to the project by the City of Wilmington via a public water system. DNREC's records indicate that the project is located within the public water service area granted to the City of Wilmington under Certificate of Public Convenience and Necessity 94-CPCN-09.
- Should dewatering points be needed during any phase of construction, a dewatering well construction permit must be obtained from the Water Supply Section prior to construction of the well points. In addition, a water allocation permit will be needed if the pumping rate will exceed 50,000 gallons per day at any time during operation.
- All well permit applications must be prepared and signed by licensed water well contractors, and only licensed well drillers may construct the wells. Please factor in the necessary time for processing the well permit applications into the construction schedule. Dewatering well permit applications typically take approximately four weeks to process, which allows the necessary time for technical review and advertising. Should you have any questions concerning these comments, please contact Rick Rios, at (302) 739-9944.

Source Water Protection Areas.

- The DNREC Source Water Protection Program has reviewed the above referenced PLUS project and determined that it does not fall within any wellhead protection or excellent groundwater recharge potential areas. However, the parcel falls entirely within the Brandywine Creek Drinking Water Watershed. This area is a Level 2 Source Water Protection Area for New Castle County.

- Level 2 Source Water Protection Areas are the delineated watershed upstream from public drinking water supply intakes. Land Use or Land Activity within these areas has the potential to influence water quality or quantity to the public drinking water system.
- DNREC recommends referring to New Castle County Unified Development Code for regulations regarding development in these water resource protection areas.

Sediment and Stormwater.

- A sediment and stormwater plan will be required for the site. Contact the reviewing agency to schedule a project application meeting to discuss the sediment and erosion control and stormwater management components of the plan as soon as possible. The site topography, soils mapping, pre- and post-development runoff, and proposed method(s) and location(s) of stormwater management should be brought to the meeting for discussion. The plan review and approval as well as construction inspection will be coordinated through the New Castle County Department of Land Use Engineering Section. Contact the Department of Land Use at (302) 395-5470 for details regarding submittal requirements and fees.

Air Quality.

- The applicant shall comply with all applicable Delaware air quality regulations. Please note that the following regulations in Table 1 – Potential Regulatory Requirements may apply to your project:

Table 1: Potential Regulatory Requirements	
Regulation	Requirements
7 DE Admin. Code 1106 - Particulate Emissions from Construction and Materials Handling	<ul style="list-style-type: none"> • Use dust suppressants and measures to prevent transport of dust off-site from material stockpile, material movement and use of unpaved roads. • Use covers on trucks that transport material to and from site to prevent visible emissions.
7 DE Admin. Code 1113 – Open Burning	<ul style="list-style-type: none"> • Prohibit open burns statewide during the Ozone Season from May 1-Sept. 30 each year. • Prohibit the burning of land clearing debris. • Prohibit the burning of trash or building materials/debris.
7 DE Admin. Code 1135 – Conformity of General Federal Actions to the State Implementation Plan	<ul style="list-style-type: none"> • Require, for any “federal action,” a conformity determination for each pollutant where the total of direct and indirect emissions would equal or exceed any of the de minimus levels (See Section 3.2.1)
7 DE Admin. Code 1141 – Limiting Emissions of Volatile Organic Compounds from Consumer and Commercial Products	<ul style="list-style-type: none"> • Use structural/ paint coatings that are low in Volatile Organic Compounds. • Use covers on paint containers when paint containers are not in use.

<p>7 DE Admin. Code 1144 – Control of Stationary Generator Emissions</p>	<ul style="list-style-type: none"> • Ensure that emissions of nitrogen oxides (NO_x), non-methane hydrocarbons (NMHC), particulate matter (PM), sulfur dioxide (SO₂), carbon monoxide (CO), and carbon dioxide (CO₂) from emergency generators meet the emissions limits established. (See section 3.2). • Maintain recordkeeping and reporting requirements.
<p>7 DE Admin. Code 1145 – Excessive Idling of Heavy Duty Vehicles</p>	<ul style="list-style-type: none"> • Restrict idling time for trucks and buses having a gross vehicle weight of over 8,500 pounds to no more than three minutes.
<p>Regulation 21 Section 10 – Emission Standards for Hazardous Air Pollutants, Asbestos</p>	<ul style="list-style-type: none"> • Ensure no visible residue of asbestos materials remains in the work area after all asbestos materials are removed in accordance with NESHAP. • Display DANGER signs whenever airborne asbestos may be present in accordance with NESHAP and OSHA • Use wet removal techniques. • Dispose of all asbestos containing waste in clearly labeled sealed containers and store in a secure location awaiting transport to an authorized disposal facility, not to exceed a period of 45 days.

For a complete listing of all Delaware applicable regulations, please look at our website:

<http://www.awm.delaware.gov/AQM/Pages/AirRegulations.aspx>.

- If a release of a Regulated Substance occurs at the proposed project site, compliance of 7 Del.C., Chapter 60; 7 Del.C., Chapter 74; and DE Admin. Code 1351, State of Delaware *Regulations Governing Underground Storage Tank Systems* (the UST Regulations) is required.
- The following (LUST) projects are located within a quarter mile from the proposed project area:
 - Lou Vollman Residence UST, Facility: 3-002220, Project: N0212092 (Inactive)
 - Stonegates Retirement Community, Facility: 3-001863, Project: N9810176, N1107123 (Inactive)
- Per the UST Regulations: Part E, § 1. Reporting Requirements:
Any indication of a Release of a Regulated Substance that is discovered by any Person, including but not limited to environmental consultants, contractors, utility companies, financial institutions, real estate transfer companies, UST Owners or Operators, or Responsible Parties shall be reported within 24 hours to:

- The Department's 24-hour Release Hot Line by calling (800) 662-8802; and
- The DNREC, Tank Management Section by calling (302) 395-2500.

Delaware State Fire Marshall's Office – Contact Duane Fox 739-4394

At the time of formal submittal, the applicant shall provide; completed application, fee, and three sets of plans depicting the following in accordance with the Delaware State Fire Prevention Regulation:

- Fire Protection Water Requirements:
 - Where a water distribution system is proposed for single family dwellings it shall be capable of delivering at least 500 gpm for 1-hour duration, at 20-psi residual pressure. Fire hydrants with 1000 feet spacing on centers are required.
 - The infrastructure for fire protection water shall be provided, including the size of water mains.
- Accessibility:
 - All premises which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads so that all buildings on the premises are accessible to fire apparatus.
 - Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.
 - The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.
 - The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.
- Gas Piping and System Information:
 - Provide type of fuel proposed, and show locations of bulk containers on plan.
- Required Notes:
 - Provide a note on the final plans submitted for review to read “ All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations”
 - Name of Water Supplier
 - Proposed Use
 - National Fire Protection Association (NFPA) Construction TypeMaximum Height of Buildings (including number of stories)

- Provide Road Names, even for County Roads

State Historic Preservation Office – Contact Terrence Burns 736-7404

- There is a known historic house (N-9556) on this parcel. According to the Pomeroy and Beers Atlas of 1868 (a 19-century historic map), it was associated with a B. Simmons, and the USGS Topographic Map of 1904 shows that the dwelling was on the parcel as well. If the development project proceeds on this parcel, the developer should be aware of the Unmarked Human Burials and Human Skeletal Remains Law, which is in Title 7, of Chapter 54, of the Delaware Code.
- Abandoned or unmarked family cemeteries are very common in the State of Delaware. They are usually in rural or open space areas, and sometimes near or within the boundary of an historic farm site. Even a marked cemetery can frequently have unmarked graves or burials outside of the known boundary line or limit. Disturbing unmarked graves or burials triggers the Delaware's Unmarked Human Burials and Human Skeletal Remains Law (7 Del. C. Ch. 54), and such remains or discoveries can result in substantial delays while the procedures required under this law are carried out. If there is a discovery of any unmarked graves, burials or a cemetery, it is very costly to have them archaeologically excavated and the burials moved. The Division of Historical & Cultural Affairs recommends that owners and/or developers have a qualified archaeological consultant investigate their project area, to the full extent, to see if there is any unmarked cemetery, graves, or burial sites. In the event of such a discovery, the Division of Historical & Cultural Affairs also recommends that the plans be re-drawn to leave the full extent of the cemeteries or any burials on its own parcel or in the open space area of the development, with the responsibility for its maintenance lying with the landowner association or development. If you would like to know more information pertaining to unmarked human remains or cemeteries, please check the following websites for additional information: www.history.delaware.gov/preservation/umhr.shtml and www.history.delaware.gov/preservation/cemeteries.shtml.
- Prior to any demolition or ground-disturbing activities, the developer may want to hire an archaeological consultant to examine the parcel for any potential archaeological site or archaeological resources, such as cemetery, burial site, or unmarked human remains.
- If there is any federal involvement with the project, in the form of licenses, permits, or funds, the federal agency, often through its client, is responsible for complying with Section 106 of the National Historic Preservation Act (36 CFR 800) and must consider their project's effects on any known or potential cultural or historic resources. Owners and developers who may plan to apply for an Army Corps of Engineers permit or for federal funding, such as HUD or USDA grants, should be aware of the National Historic Preservation Act of 1966 (as amended). Regulations promulgated for Section 106 of this Act stipulate that no ground-disturbing or demolition activities should take place before the Corps or other involved federal agency determines the area of potential effect of the project undertaking. These stipulations are in place to allow for comment from the public,

the Delaware State Historic Preservation Office, and the Advisory Council for Historic Preservation about the project's effects on historic properties. Furthermore, any preconstruction activities without adherence to these stipulations may jeopardize the issuance of any permit or funds. If you need further information or additional details pertaining to the Section 106 process and the Advisory Council's role, please review the Advisory Council's website at www.achp.gov.

Recommendations/Additional Information

This section includes a list of site specific suggestions that are intended to enhance the project. These suggestions have been generated by the State Agencies based on their expertise and subject area knowledge. **These suggestions do not represent State code requirements.** They are offered here in order to provide proactive ideas to help the applicant enhance the site design, and it is hoped (**but in no way required**) that the applicant will open a dialogue with the relevant agencies to discuss how these suggestions can benefit the project.

Department of Transportation – Contact Bill Brockenbrough 760-2109

- Be advised that DelDOT will take into account the Brandywine Valley Byway Corridor Management Plan in our review of the plans for this project. While the Plan primarily addresses actions that DelDOT will take, those actions do extend to the review of subdivision, land development and entrance plans. The Plan is available at the following link:
http://www.deldot.gov/information/community_programs_and_services/byways/brandywine_cmp.shtml.
- While the size and trip generation of the proposed development do not warrant a pre-submittal meeting, considering its location and the issues mentioned above, one may be appropriate. We recommend that the developer's engineer contact Mr. Kevin Hickman of this office to discuss these matters and to meet with him as necessary. Mr. Hickman can be reached at (302) 760-2461.


Department of Natural Resources and Environmental Control – Contact Michael Tholstrup 735-3352

Bog Turtle.

- Habitats of the federally protected bog turtle (*Glyptemys muhlenbergii*) have been identified both east and west of the project area. However, it does not appear that the project will affect this species.

Soils Assessment.

- Based on the NRCS soil survey mapping update, the primary soil mapping unit mapped on subject parcel is Glenelg (GeB). Glenelg is a well-drained upland soil that, generally, has few limitations for development.



Additional information on TMDLs and water quality.

- A Pollution Control Strategy (PCS) to achieve the required TMDL nutrient and bacterial load reduction requirements has been established for the greater Christina Basin. The web link for the Christina watershed PCS strategies is as follows:
<http://www.dnrec.delaware.gov/swc/wa/Pages/WatershedManagementPlans.aspx>
- DNREC strongly encourages the applicant reduce nutrient and bacterial pollutants on their parcel through voluntary implementation of the following recommended BMPs:
 - Maintain as much of the existing open space as possible; we further suggest planting additional native tree and native herbaceous planting wherever possible.

- Calculate all post-construction surface imperviousness with all forms of created (or constructed) surface imperviousness (e.g., rooftops, driveways, parking lots, sidewalks, ponds, and/or “pond-like” open-water storm water management structures, and roads) included.
- Use green-technology storm water management structures (in lieu of open-water management structures) and rain gardens as BMPs to reduce nutrient pollutant impacts. Please contact Lara Allison at (302) 739-9939 for further information about siting rain gardens on this parcel.
- Use pervious paving materials (e.g., pervious pavers) as a BMP (i.e., substitute for conventionally paved asphalt or concrete parking areas and roads) to help mitigate impacts from flooding and pollutant runoff to waters of the greater Christina River watershed.
- Assess nutrient and bacterial pollutant loading at the preliminary project design phase. To this end, the Watershed Assessment Section has developed a methodology known as the “Nutrient Load Assessment protocol.” The protocol is a tool used to assess changes in nutrient loading (e.g., nitrogen and phosphorus) that result from the conversion of individual or combined land parcels to a different land use, while providing applicants with quantitative information about their project’s impact on baseline water quality. We strongly encourage the use of this protocol to help design and implement the most effective BMPs. Please contact John Martin or Jen Walls at (302) 739-9939 for more information.

Additional information on tank management.

- When contamination is encountered, PVC pipe materials should be replaced with ductile steel and nitrile rubber gaskets in the contaminated areas.
- If any aboveground storage tanks (ASTs) less than 12,500 gallons are installed, they must be registered with the DNREC Tank Management Section (TMS). If any ASTs greater than 12,500 gallons are installed, they are also subject to installation approval by the TMS.

Additional information on air quality.

- Currently, the properties are occupied by three homes and related structures at the northern extent. The site plan shows that two of these homes and their related structures will be demolished, in order to facilitate a reconfiguration for seven homes. As such, the DNREC Division of Air Quality (DAQ) has provided asbestos information.

- There is an opportunity to connect the project to a transit network via an existing DART bus stop located within walking distance of the property on Kennett Pike. This stop is served by bus route 10, which connects the train station in downtown Wilmington to points along Kennett Pike in north Wilmington.
- DNREC encourages developers and builders to consider all sustainable growth practices in their design, and we believe that the air quality impacts associated with the project should be completely considered. New homes may emit, or cause to be emitted, additional air contaminants into Delaware’s air, which will negatively impact public health, safety and welfare. These negative impacts are attributable to:
 - Emissions that form ozone and fine particulate matter; Delaware currently violates federal health-based air quality standards for ozone. New Castle County, Delaware is classified as non-attainment for not meeting federal and state 8-hour ozone standards. Compared to Kent and Sussex Counties, short term 1-hour average peak ozone levels are usually highest in New Castle County, as well,
 - The emission of greenhouse gases which are associated with climate change, and
 - The emission of air toxics.
- Air emissions generated from new homes include emissions from the following activities:
 - Area sources such as painting, maintenance equipment and the use of consumer products like roof coatings and roof primers.
 - The generation of electricity, and
 - All transportation activity.
- Based on the information provided, the three air emissions components (i.e., area, electric power generation, and mobile sources) were quantified. Table 2 – Projected Air Quality Emissions represents the actual impact Stone Brook may have on air quality.

Emissions Attributable to Stone Brook (Tons per Year)	Volatile Organic Compounds (VOC)	Nitrogen Oxides (NOx)	Sulfur Dioxide (SO ₂)	Fine Particulate Matter (PM _{2.5})	Carbon Dioxide (CO ₂)
Area source emissions	0.2	*	*	*	0.9
Power emissions	*	0.1	0.3	*	*
Mobile emissions	0.3	0.3	*	*	206.9
Total emissions	0.5	0.4	0.3	*	207.8

(*) Indicates data is not available.

Note that emissions associated with the actual construction of the residential community, including automobile and truck traffic from working in, or delivering products to the site, as well as site preparation, earth moving activities, road paving and other miscellaneous air emissions, are not reflected in the table above.

- DNREC encourages sustainable growth practices that:
 - Control sprawl;
 - Preserve rural and forested areas;
 - Identify conflicting land use priorities;
 - Encourage growth on previously developed sites and denser communities while at the same time protect our diminishing land base;
 - Coordinate transportation, housing, environment, and climate protection plans with land use plans; and
 - Demonstrate that communities can achieve the qualities of privacy, community, and contact with nature without degrading the natural environment or generating unacceptable environmental costs in terms of congestion, use of natural resources, or pollution.

- Additional measures may be taken to substantially reduce the air emissions identified above. These measures include:
 - **Constructing with only energy efficient products.** Energy Star qualified products are up to 30% more energy efficient. Savings come from building envelope upgrades, high performance windows, controlled air infiltration, upgraded heating and air conditioning systems, tight duct systems and upgraded water-heating equipment. Every percentage of energy efficiency translates into a percent reduction in pollution. The Energy Star Program is an excellent way to save on energy costs and reduce air pollution.

 - **Offering geothermal and/or photo voltaic energy options.** These systems can significantly reduce emissions from electrical generation and from the use of oil or gas heating equipment.

 - **Constructing with high albedo, high solar reflectance materials.** This includes roofing and hardscape. These materials help to reduce heat island impacts and, by extension, help to minimize the potential for localized ground-level ozone formation. These materials also help reduce demands on air conditioning systems and save on energy costs.

 - **Providing shade for parking lot areas.** Approaches may include architectural devices, vegetation, or solar panels. Providing shade for parking areas helps to reduce heat island impacts, and, by extension, helps to minimize the potential for localized ground-level ozone formation. Such measures can also have the additional benefit of channeling or infiltrating stormwater.

- **Encouraging the use of safe multimodal transportation.** This measure can significantly reduce mobile source emissions. For every vehicle trip that is replaced by the use of a sidewalk, bike path, or mass transit, 7 pounds of VOC and 11.5 pounds of NOx are reduced each year. There is an opportunity to connect the project to a transit network via an existing DART bus stop located within walking distance of the property on Kennett Pike.
- **Using retrofitted diesel engines during construction.** This includes equipment that is on-site as well as equipment used to transport materials to and from site.
- **Using pre-painted/pre-coated flooring, cabinets, fencing, etc.** These measures can significantly reduce the emission of VOCs from typical architectural coating operations.
- **Planting trees in vegetative buffer areas.** Trees reduce emissions by trapping dust particles and replenishing oxygen. Trees also reduce energy emissions by cooling during the summer and by providing wind breaks in the winter, whereby reducing air conditioning needs by up to 30 percent and saving 20 to 50 percent on fuel costs.

This is a partial list, and there are additional things that can be done to reduce the impact of the development. The applicant should submit a plan to the DNREC Division of Air Quality (DAQ) which addresses the above listed measures, and that details all of the specific emission mitigation measures that will be incorporated into the Stone Brook project. The DAQ point of contact is Rachel Yocum, and she may be reached at (302) 739-9402 or Rachel.yocum@state.de.us.

Delaware State Fire Marshall's Office – Contact John Rudd 323-5365

- Preliminary meetings with fire protection specialists are encouraged prior to formal submittal. Please call for appointment. Applications and brochures can be downloaded from our website: www.statefiremarshal.delaware.gov, technical services link, plan review, applications or brochures.

Following receipt of this letter and upon filing of an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason therefore.

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,

A handwritten signature in cursive script that reads "Constance C. Holland". The signature is written in black ink and is positioned above the typed name and title.

Constance C. Holland, AICP
Director, Office of State Planning Coordination

CC: New Castle County