STATE OF DELAWARE
OFFICE OF MANAGEMENT AND BUDGET
OFFICE OF STATE PLANNING COORDINATION

March 27, 2024

Ronald H. Sutton, Jr.
Civil Engineering Associates, LLC.
55 W Main Street
Middletown, DE 19709

RE: PLUS review – 2024-02-02; Sunset Lake Properties, LLC & Christiana Excavating Company

Dear Mr. Sutton:

Thank you for meeting with State agency planners on February 28, 2024 to discuss the Sunset Lake Properties, LLC & Christiana Excavating Company project. According to the information received, you are seeking review of a proposed rezoning and site plan to construct two warehouse buildings and rezone from ST to I.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State, and local regulations regarding this property. We also note that as New Castle County is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the County.**

Strategies for State Policies and Spending

The properties are located within Investment Level 1 according to the 2020 Strategies for State Policies and Spending. It is located in unincorporated New Castle County. The future land use designation in the comprehensive plan is Business Flex, which is compatible with the desired Industrial zoning district and no amendments are necessary.

Investment Level 1 reflects areas that are already developed in an urban or suburban fashion, where infrastructure is existing or readily available, and where future redevelopment or infill projects are expected and encouraged by State policy. Future development on this site in Level 1 is consistent with the 2020 Strategies for State Policies and Spending; therefore, the Office of State Planning Coordination has no objections to this rezoning and site plan, provided it meets all New Castle County regulations.

Code Requirements/Agency Permitting Requirements

Department of Transportation – Contact Stephen Bayer 302-760-4834

- Any site access points onto State maintained roads must be designed in accordance with DelDOT's Development Coordination Manual, which is available at http://www.deldot.gov/Business/subdivisions/index.shtml?dc=changes.

- Pursuant to Section 1.3 of the Development Coordination Manual, a Pre-Submittal Meeting is required before plans are submitted for review. The form needed to request the meeting and guidance on what will be covered there and how to prepare for it is located at https://www.deldot.gov/Business/subdivisions/pdfs/Meeting_Request_Form.pdf?08022017.

- Section 1.7 of the Development Coordination Manual addresses fees that are assessed for the review of development proposals. DelDOT anticipates collecting the Initial Stage Fee when the record plan is submitted for review and the Construction Stage Fee when construction plans are submitted for review.

- As necessary, in accordance with Section 3.2.5 and Figure 3.2.5-a of the Development Coordination Manual, DelDOT will require dedication of right-of-way along the site's frontage. By this regulation, this dedication is to provide a minimum of 30 feet of right-of-way from the physical centerline of Sunset Lake Road (Rt. 72). The following right-of-way dedication note is required, "**An X-foot wide strip of right-of-way from the centerline is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- In accordance with Section 3.2.5.1.2 of the Development Coordination Manual, DelDOT will require the establishment of a 15-foot wide permanent easement across the property frontage. The location of the easement shall be outside the limits of the ultimate right-of-way. The easement area can be used as part of the open space calculation for the site. The following note is required, "**A 15-foot wide permanent easement is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- Referring to Section 3.4.2.1 of the Development Coordination Manual, the following items, among other things, are required on the Record Plan:

    - A Traffic Generation Diagram. See Figure 3.4.2-a for the required format and content.

  - Notes identifying the type of off-site improvements, agreements (signal, letter) contributions and when the off-site improvements are warranted.

- Section 3.5.4.2 of the Development Coordination Manual addresses requirements for Shared Use Paths (SUP) and sidewalks. For projects in Level 1 Investment Areas, installation of paths or sidewalks along the frontage on State-maintained roads is required.

- In accordance with Section 3.8 of the Development Coordination Manual, storm water facilities, excluding filter strips and bioswales, shall be located a minimum of 20 feet from the ultimate State right-of-way along all frontage roads.

- In accordance with Section 5.2.9 of the Development Coordination Manual, the Auxiliary Lane Worksheet should be used to determine whether auxiliary lanes are warranted at the site entrances and how long those lanes should be. The worksheet can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.4 of the Development Coordination Manual, sight distance triangles are required and shall be established in accordance with American Association of State Highway and Transportation Officials (AASHTO) standards. A spreadsheet has been developed to assist with this task. It can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.14 of the Development Coordination Manual, all existing utilities must be shown on the plan and a utility relocation plan will be required for any utilities that need to be relocated.

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Staff from the Delaware Department of Natural Resources and Environmental Control (DNREC) reviewed the project submitted for PLUS review. The absence of comments regarding specific resources does not indicate that there are not additional constraints or environmental issues on the site, nor does it indicate DNREC support of a project.

- DNREC reviewers have no comments or concerns at this time.

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Proposed Project Parcel Flood Concern

- This parcel is primarily located within an area of **Minimal Flood Concern of 1000 years or greater** and therefore no direct concern.

Parcel Status within County Evacuation Zone Location

- The parcel is **not** yet located within a New Castle County Evacuation Zone.

Parcel Status within the 10-mile Emergency Planning Zone (EPZ) for the Salem Nuclear Power Plant

- The parcel **is not** located within the 10-mile EPZ for the Salem Nuclear Power Plant.

State Historic Preservation Office – Contact Carlton Hall 302-736-7400

- There are no known archaeological sites or known National Register-listed or eligible properties within the project area.

- Area has moderate to high potential for precontact and historic period archaeological resources in the project area; however, significant activity in the parcel has likely disturbed any archaeological resources, should they be present. This office has no archaeological concerns related to the proposed project.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
This document is for information purposes only and does not constitute any type of approval from the Delaware State Fire Marshal's Office.

- This Agency has no objection to the re-zoning request. The information provided below shall be considered when plans are being designed.

At the time of formal submittal, the applicant shall provide; completed application, fee, and three sets of plans depicting the following in accordance with the Delaware State Fire Prevention Regulation (DSFPR):

Fire Protection Water Requirements

- Water distribution system capable of delivering at least 1500 gpm for 2-hour duration, at 20-psi residual pressure is required. Fire hydrants with 800 feet spacing on centers. (Storage)

- Where a water distribution system is proposed for the site, the infrastructure for fire protection water shall be provided, including the size of water mains for fire hydrants and sprinkler systems.

Fire Protection Features

- All structures over 10,000 Sq. Ft. aggregate will require automatic sprinkler protection installed.

- Buildings greater than 10,000 sqft, 3-stories or more, over 35 feet, or classified as High Hazard, are required to meet fire lane marking requirements.

- Show Fire Department Connection location (Must be within 300 feet of fire hydrant), and detail as shown in the DSFPR.

- Show Fire Lanes and Sign Detail as shown in DSFPR.

Accessibility

- All premises, which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads, and fire lanes so that all buildings on the premises are accessible to fire apparatus. This means that the access road to the subdivision from Sunset Lake Road must be constructed so fire department apparatus may negotiate it.

- Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.

- Any dead-end road more than 300 feet in length shall be provided with a turn-around or cul-de-sac arranged such that fire apparatus will be able to turn around by making not more than one backing maneuver. The minimum paved radius of the cul-de-sac shall be 38 feet. The dimensions of the cul-de-sac or turn-around shall be shown on the final plans. Also, please be advised that parking is prohibited in the cul-de-sac or turn around.

- The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.

- The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.

Gas Piping and System Information

- Provide type of fuel proposed and show locations of bulk containers on plan.

Required Notes

- Provide a note on the final plans submitted for review to read "All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations."
- Proposed Use
- Alpha or Numerical Labels for each building/unit for sites with multiple buildings/units
- Square footage of each structure (Total of all Floors)
- National Fire Protection Association (NFPA) Construction Type
- Maximum Height of Buildings (including number of stories)
- Note indicating if building is to be sprinklered
- Name of Water Provider
- Letter from Water Provider approving the system layout
- Provide Lock Box Note (as detailed in DSFPR) if Building is to be sprinklered
- Provide Road Names, even for County Roads

Recommendations/Additional Information

This section includes a list of site-specific suggestions that are intended to enhance the project. These suggestions have been generated by the State Agencies based on their expertise and subject area knowledge. **These suggestions do not represent State code requirements.** They are offered here in order to provide proactive ideas to help the applicant enhance the site design, and it is hoped **(but in no way required)** that the applicant will open a dialogue with the relevant agencies to discuss how these suggestions can benefit the project.

Department of Transportation – Contact Stephen Bayer 302-760-4834

- The applicant should expect a requirement that all PLUS and Technical Advisory Committee (TAC) comments be addressed prior to submitting plans for review.

- Please be advised that the Standard General Notes have been updated and posted to the DelDOT website. Please begin using the new versions and look for the revision dates of March 21, 2019 and March 16, 2021. The notes can be found at https://www.deldot.gov/Business/subdivisions/

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Population

- The county has a population density of 1321.50 per square mile based on the US 2020 Census report; an increase from 2010 at 1241.00 persons per square mile.

- The specific census block(s) the project is located on has a total population of 1,214, though, with development, this will undoubtedly change.

- The 18 adjacent blocks aggregated bring the area to a total population of 2,979.

FEMA National Risk Index

- The FEMA National Risk Index is an online mapping application that identifies communities most at risk to 18 natural hazards: Avalanche, Coastal Flooding, Cold Wave, Drought, Earthquake, Hal, Heat Wave, Hurricane, Ice Storm, Landslide, Lightning, Riverine Flooding, Strong Wind, Tornado, Tsunami, Volcanic Activity, Wildfire, and Winter Weather. The FEMA National Risk Index is calculated by multiplying the Expected Annual Loss times the Social Vulnerability and dividing that by the Community Resilience.

Expected Annual Loss
× Social Vulnerability
÷ Community Resilience

= Risk Index

- According to FEMA's National Risk Index, the parcel **is** considered **very low** for overall natural hazards risks.

- Community Resilience is a consequence reduction risk component and a community risk factor that represents the ability of a community to prepare for anticipated natural hazards, adapt to changing conditions and withstand/recover rapidly from disruptions. Social Vulnerability is a consequence-enhancing risk factor that represents the susceptibility of social groups to the adverse impacts of natural hazards.

- Its community resilience is rated at **relatively high** whereas its social vulnerability is rated as **relatively moderate.**

Renewable Energy Commitment

- Regarding energy use and consumption, the parcel utilizes **utility/natural gas** as the predominant fuel type for heating purposes.

- DEMA strongly encourages the use of renewable energies and high-efficiency appliances and utilities. Regarding utilities, DEMA suggests incorporating 90% series furnaces/HVAC systems; the closer to 99%, the better, as well as A/C units of 20 Seer or greater. DEMA recommends using tankless water heaters, and battery backup systems for sump pumps to reduce potential water damage from power failure.

- Lastly, DEMA encourages the integration of modern and emerging technologies, such as the potential for electric vehicles in garages/parking lots, green roofs or solar panels where applicable and allowable, and the like.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394

- Preliminary meetings with fire protection specialists are encouraged prior to formal submittal. Please call for appointment. Applications and brochures can be downloaded from our website: www.statefiremarshal.delaware.gov, technical services link, plan review, applications or brochures.

Following receipt of this letter and upon filing of an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason, therefore.

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,



David L. Edgell, AICP
Director, Office of State Planning Coordination