STATE OF DELAWARE
OFFICE OF MANAGEMENT AND BUDGET
OFFICE OF STATE PLANNING COORDINATION

February 20, 2025

Mark Davidson
Pennoni Associates, Inc
18072 Davidson Drive
Milton, DE 19968

RE: PLUS review – 2025-01-04; Greenwood Garden Apartments Concept Plan

Dear Mr. Davidson:

Thank you for meeting with State agency planners on January 22, 2025, to discuss Greenwood Garden Apartments Concept Plan. According to the information received, you are seeking review of a proposed rezoning and site plan for a 72-unit multifamily neighborhood featuring garden-style apartment dwellings. The 7.9-acre site, currently vacant, is zoned R-1 (Single-Family Residential District) with a proposed rezoning to R-3 (Garden Apartment and Townhouse District) and is classified as State Strategies Level 2.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State, and local regulations regarding this property. We also note that the Town of Greenwood is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the Town.**

Strategies for State Policies and Spending

This project is located in a Level 2 investment area, which is consistent with the 2020 Strategies for State Policies and Spending. This site is also located in the Town of Greenwood.

Investment Level 2 reflects areas where growth is anticipated by local, county, and State plans in the near-term future. Development in Level 2 is consistent with the 2020 Strategies for State Policies and Spending. While the Office of State Planning Coordination generally has no objections to development in a level 2 area, this site may have some environmental issues that should be discussed before the Town makes a decision on this site plan.

Per DNREC, Approximately two-thirds of this parcel lies within the mapped 100-year floodplain (1% annual chance of flooding), with 6 apartment buildings proposed either fully or partially

within in the mapped 100-year (zone AE) and 4 apartment buildings located in the 500-year floodplain. Internal roadways are also proposed within the 100-year floodplain and 500-year floodplain. Flooding and drainage issues on this site have already been documented. Increased frequency of intense rainfall is expected to expand the area of the floodplain in this region and exacerbate the existing flooding and drainage issues on this site.

Due to the high probability for most of this site to flood, combined with poorly drained C/D soils across the entirety of the site, development of this site in this manner is not recommended. Building in flood prone areas is not recommended due to the risk of flood damage, loss, and inaccessibility to first responders in the event of an emergency.

It is noteworthy that the 100-year floodplain is currently considered to be Out of Play in New Castle County, Kent County, and several municipalities due to these types of risks.

Code Requirements/Agency Permitting Requirements

Office of State Planning Coordination – Contact Dorothy Morris 302-739-3090

- According to the Town of Greenwood comprehensive plan this parcel is zoned R-1 (Low Density Residential). The Future Land Use map designation for the parcel is Agriculture. If the owner intends to rezone to R-3, the town will need to do a comprehensive plan amendment to the Future Land Use map. It is my understanding the town is working on a comprehensive plan amendment for several parcels within the town. The owner should contact the town to request that a change to the Future Land Use classification for this parcel be part of that amendment.

Department of Transportation – Contact Stephen Bayer 302-760-4834

- As presented and discussed in the PLUS meeting the developer does not anticipate the internal streets being state maintained. Please confirm if that is still the developer's intent and the process continues.

- The site access on all State maintained roads must be designed in accordance with DelDOT's Development Coordination Manual, which is available at http://www.deldot.gov/Business/subdivisions/index.shtml?dc=changes.

- Pursuant to Section P.3 of the Manual, a Pre-Submittal Meeting is required before plans are submitted for review. The form needed to request the meeting and guidance on what will be covered there and how to prepare for it is located at https://www.deldot.gov/Business/subdivisions/pdfs/Meeting_Request_Form.pdf?08022017.

- Section P.5 of the Manual addresses fees that are assessed for the review of development proposals. DelDOT anticipates collecting the Initial Stage Fee when the record plan is submitted for review and the Construction Stage Fee when construction plans are submitted for review.

- In terms of traffic analysis and based on the expected trip generation this project would qualify for an Area Wide Study Fee (AWSF). Please contact the DelDOT offices to move forward with this process.

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Staff from the Delaware Department of Natural Resources and Environmental Control (DNREC) reviewed the project submitted for PLUS review. The absence of comments regarding specific resources does not indicate that there are not additional constraints or environmental issues on site, nor does it indicate DNREC support of a project.

Special Flood Hazard Area
According to the newest Flood Insurance Rate Maps (FIRM), a portion of this parcel is situated within a Special Flood Hazard Area, specifically within the mapped 100-year floodplain (1% annual chance of flooding). The Special Flood Hazard Area identified on the site lies within zone AE. In lands contained within the 100-year floodplain, the National Flood Insurance Program's floodplain management regulations must be enforced through the local floodplain ordinance, which can have higher standards. Structures and features such as residences and internal roadways are proposed within the floodplain. The mortgage lender may require the property owner to obtain flood insurance. Additionally, the property manager may require tenants to obtain flood insurance policies (for contents only). Although some rental units are proposed outside of the Special Flood Hazard Area (SFHA), the property owner may still be required by lenders to purchase flood insurance, based on the proximity to the SFHA.

A portion of this site is also situated within the moderate risk floodplain, or 500-year floodplain (0.2% annual chance of flooding), identified as a shaded zone-X.

Building in this manner is considered unsafe for residents due to the future vulnerability of this particular location. Roads are essential for first responders in the event of an emergency and could become impassable during flooding events. The following requirements apply:

- The applicant must comply with the local floodplain ordinance and regulations applicable to development or construction within the 100-year floodplain. In determining the boundary of the floodplain, use the most recent FIRM maps available, which can be found at https://floodplanning.dnrec.delaware.gov/

- If fill is to be placed in floodplain to increase grade elevation to raise proposed development out of the mapped floodplain, the applicant must work with the local community floodplain authority to initiate a Certified Letter of Map Revision – Fill (CLOMR-Fill) request. A CLOMR-Fill request should be submitted to FEMA for review followed by an application to FEMA for a Letter of Map Revision (LOMR) at completion. Please note that a property will not be officially recognized by FEMA as being located out of the mapped floodplain until a LOMR has been issued. To determine the community floodplain authority for this proposal, please contact DNREC's Shoreline and Waterway Management Section.

Contact: DNREC Shoreline and Waterway Management Section at (302) 608-5500.
Website: https://dnrec.delaware.gov/watershed-stewardship/waterways/floodplains/

Tax Ditches
Several tax ditches border and transect this property. Tax ditches are man-made channels created to move normal water flow off agricultural lands. These channels have associated tax ditch Rights-of-Way (ROW) that are utilized for access as well as sediment and debris disposal during maintenance. Tax ditch ROWs vary by channel size and location. The following tax ditches and associated ROWs exist on this site:

- The Main Prong of the Cart Branch Tax Ditch lies on the western property boundary and has a 55-foot to Centerline (CL) ROW extending east from the property boundary.

- Prong 4 of the Cart Branch Tax Ditch lies on the southern portion of the property and has a 78-foot to Centerline (CL) ROW extending northward. Apartments and parking lots are proposed in these areas.

- Prong A of the Cart Branch Tax Ditch lies on the northern property boundary and has a 15-foot to Centerline (CL) ROW extending into the property boundary. Road crossings will impact this ROW at Maryland Avenue and Sussex Avenue.

Proposed structures or construction lies within the existing tax ditch ROW. To reduce or change existing tax ditch ROWs, a Court Order Change must be submitted by the DNREC Drainage Program. The associated Land Development Project Review Request form is attached, as well as the aerial drainage map.

- Please clearly map and label existing and proposed Cart Branch Tax Ditch Prong A, Main Channel and Prong 4 and associated Right-of-Way (ROW) on all sheets where it appears, including on adjacent properties. The Delaware Tax Ditch FeatureServer is available on DE FirstMap and here:

https://enterprise.firstmap.delaware.gov/arcgis/rest/services/Hydrology/DE_TaxDitch/FeatureServer

- If the site and/or stormwater management features are designed to discharge into any of the Prongs of the Cart Ditch Tax Ditch, design must consider existing conditions versus design specifications. Please consult with the DNREC Drainage Program for As-Built design information if necessary.

- Contact the DNREC Drainage Program to discuss the on-site tax ditch ROWs prior to the project application meeting with the appropriate plan review agency for construction stormwater management.

- Permanent obstructions including, but not limited to, stormwater management facilities, buildings, sheds, streets, wells, and septic systems are not allowed within the tax ditch ROWs.

- Existing tax ditches on the property must be surveyed and compared to tax ditch design specifications for effective function. The channel should be cleared or excavated prior to the construction of the project if needed.

- All precautions should be taken to ensure the project does not hinder any off-site drainage upstream or create any off-site drainage problems downstream due to increases in stormwater.

Contact: DNREC Drainage Program at (302) 855-1930.
Website: https://dnrec.delaware.gov/drainage-stormwater/
Tax Ditch Mapper: de.gov/taxditchmap
Tax Ditch guidelines: https://documents.dnrec.delaware.gov/swc/Drainage/Documents/Tax-Ditch-Land-Development-Guidelines.pdf

Stormwater Management
The project proposes greater than 5,000 square feet of land disturbing activities and will be subject to Delaware's *Sediment and Stormwater Regulations*.

- A Sediment and Stormwater Plan must be developed, then approved by the appropriate plan review agency, prior to any land disturbing activity taking place on the site. For this project, the plan review agency is the Sussex Conservation District.

- Additionally, to address federal requirements, construction activities that exceed 1.0 acre of land disturbance require Construction General Permit coverage through submittal of an electronic Notice of Intent for Stormwater Discharges Associated with Construction Activity. This form must be submitted electronically

https://enoi.dnrec.delaware.gov/, (select Construction Stormwater General Permit) to the DNREC Division of Watershed Stewardship, along with the $195 fee.

- Schedule a project application meeting with the appropriate plan review agency prior to moving forward with the stormwater and site design. As part of this process, you must submit a Stormwater Assessment Study.

Plan review agency contact: Sussex Conservation District at (302) 856-2105 or (302) 856-7219. Website: https://www.sussexconservation.org/

General Stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Hydrologic Soils Group
Hydrologic Soil Group C and D, poorly drained soils, have been identified on the entire site. These soil types could worsen existing drainage issues if present and are typically not conducive to utilizing infiltration stormwater Best Management Practices such as bioretention and infiltration basins. These practices must meet minimum infiltration requirements.

- Any stormwater Best Management Practices that propose the use of infiltration or natural recharge shall include a soils investigation.

Contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Wastewater Disposal Systems – Large Systems
For wastewater conveyance offsite by way of a new sewer connection, flow rates exceeding 2,500 gallons of liquid waste per day will require a Wastewater Pollution Collection and Conveyance (WPCC) permit from the Commercial and Government Services section.

Contact: DNREC Commercial and Government Services Section at (302) 739-9948.
Website: https://dnrec.delaware.gov/water/commercial-government/

Wetlands and Waterways
Maps from the Statewide Wetlands Mapping Project indicate the presence of a perennial stream (Cart Branch) located along the western property boundary. The application states that the project does not propose direct impacts to the waterway.

State Requirements:

- If plans change and wetlands are disturbed, please contact the Wetlands and Waterways Section for more information on permitting requirements.

State Contact: DNREC Wetlands and Waterways Section at (302) 739-9943.
Website: https://dnrec.delaware.gov/water/wetlands/

Electric Vehicle Charging Requirements
Electric vehicle charging infrastructure is now required for all residential dwellings in Delaware (see 80 Del. Laws, c. 145 § 8001- § 8006) for which:

1. A building permit is issued on or after January 1, 2024 (single family), or

2. The final site plan is approved on or after January 1, 2025 (multi-family).

Requirements are summarized below. Consult the Delaware Code directly for further details.

Multi-family Dwellings, effective 2025:

- The developer of a multi-family residential dwelling shall install electric vehicle parking spaces, where at least 5% of the total parking spaces for the multi-family residential dwelling must be electric vehicle capable parking spaces.

- In addition, a developer of a multi-family residential dwelling shall provide at least one electric vehicle charging infrastructure parking space in an area available for use by all residents of the multi-family residential dwelling (example: community centers).

- Construction documents must indicate the location of proposed electric vehicle charging infrastructure parking spaces and electric vehicle capable parking spaces.

- Parking space dimensions must comply with the county or municipal building code applicable to the multi-family residential dwelling.

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Proposed Project Parcel Flood Concern

- Approximately 50% of this parcel is located within an area of **1% Annual Chance Flood Hazard Area** or **100-year flood plane** identified as a **Special Flood Hazard Area Flood Zone AE**. Another approximately 25% of the parcel falls within a **500-year flood plain** or **0.3% Annual Chance Flood Hazard Area**, bringing the total area of the parcel contained within some type of flood zone to 75%.



Parcel Status within County Evacuation Zone Location

- This parcel is not yet located within a Sussex County Evacuation Zone.

Parcel Status within the 10-mile Emergency Planning Zone (EPZ) for the Salem Nuclear Power Plant

- The parcel **is not** located within the 10-mile EPZ for the Salem Nuclear Power Plant.

<u>State Historic Preservation Office – Contact Carlton Hall 302-736-7400</u>

- The parcel borders Cart Branch and is just south of Greenwood. The parcel has poorly drained soils. The parcel has been agricultural fields with a wooded area in the southern tip for the majority of the 20th century. There are multiple archaeological sites within a mile of the parcel.

- Due to the proximity to these archaeological sites, we recommend an archaeological survey prior to any ground disturbing activities. If any project or development proceeds, the developer should be aware of the Unmarked Human Burials and Human Skeletal Remains Law (Del. C. Title 7, Ch.54).

  If there are any questions, inquiries, or concerns, feel free to contact the Delaware State Historic Preservation Office for assistance at 302-736-7400.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
This document is for information purposes only and does not constitute any type of approval from the Delaware State Fire Marshal's Office.

Fire Protection Water Requirements:

- Water distribution system capable of delivering at least 1000 gpm for 1-hour duration, at 20-psi residual pressure is required. Fire hydrants with 800 feet spacing on centers. Where a water distribution system is proposed for the site, the infrastructure for fire protection water shall be provided, including the size of water mains for fire hydrants and sprinkler systems.

Fire Protection Features:

- All structures over 10,000 sq. Ft. aggregate will require automatic sprinkler protection installed.

- Buildings greater than 10,000 sq. ft., 3-stories or more, over 35 feet, or classified as High Hazard, are required to meet fire lane marking requirements

- Show Fire Department Connection location (Must be within 300 feet of fire hydrant), and detail as shown in the DSFPR.

- Show Fire Lanes and Sign Detail as shown in DSFPR

Accessibility

- All premises, which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads, and fire lanes so that all buildings on the premises are accessible to fire apparatus. This means that the access road to the subdivision from Addix Avenue, Maryland Avenue, and Sussex Avenue must be constructed so fire department apparatus may negotiate it.

- Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.

- Any dead-end road more than 300 feet in length shall be provided with a turn-around or cul-de-sac arranged such that fire apparatus will be able to turn around by making not more than one backing maneuver. The minimum paved radius of the cul-de-sac shall be 38 feet. The dimensions of the cul-de-sac or turn-around shall be shown on the final plans. Also, please be advised that parking is prohibited in the cul-de-sac or turn around.

- The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.

- The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.

Gas Piping and System Information:

- Provide type of fuel proposed and show locations of bulk containers on plan.

Required Notes:

- Provide a note on the final plans submitted for review to read "All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations."
- Proposed Use
- Alpha or Numerical Labels for each building/unit for sites with multiple buildings/units
- Square footage of each structure (Total of all Floors)
- National Fire Protection Association (NFPA) Construction Type
- Maximum Height of Buildings (including number of stories)
- Townhouse 2-hr separation wall details shall be shown on site plans
- Note indicating if building is to be sprinklered
- Name of Water Provider
- Letter from Water Provider approving the system layout
- Provide Lock Box Note (as detailed in DSFPR) if Building is to be sprinklered
- Provide Road Names, even for County Roads

Recommendations/Additional Information

This section includes a list of site-specific suggestions that are intended to enhance the project. These suggestions have been generated by the State Agencies based on their expertise and subject area knowledge. **These suggestions do not represent State code requirements.** They are offered here in order to provide proactive ideas to help the applicant enhance the site design, and it is hoped **(but in no way required)** that the applicant will open a dialogue with the relevant agencies to discuss how these suggestions can benefit the project.

Department of Transportation – Contact Stephen Bayer 302-760-4834

- The applicant should expect a requirement that all PLUS and Technical Advisory Committee (TAC) comments be addressed prior to submitting plans for review.

- Please be advised that the Standard General Notes have been updated and posted to the DelDOT website. Please begin using the new versions and look for the revision dates of March 21, 2019 and March 16, 2021. The notes can be found at https://www.deldot.gov/Business/subdivisions/

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Special Flood Hazard Area

- Consider other design alternatives for this site to locate all structures, parking lots, and internal roadways well outside of the floodplain.

- Specifically, it is not recommended to place in the floodplain roadways that are essential for first responders in the event of an emergency. Roadways in the floodplain could become impassable during major flooding events. Safe access to such locations should be ensured at all times.

- Avoid increasing the grade elevation and bulk grading on the site. Such practices have the potential to worsen flooding on adjacent properties.

- DNREC reviewers recommend that hydrologic and hydraulic engineering analyses are conducted for this site. These studies will determine base flood elevations and floodway delineations.

Contact: DNREC Shoreline and Waterway Management Section at (302) 608-5500.
Website: https://dnrec.delaware.gov/watershed-stewardship/waterways/floodplains/

Tax Ditches

- All existing ditches on the property should be evaluated for function and cleaned, if needed, prior to the construction of the project.

- Environmental permits or exemptions may be required by the County Conservation District (Standard Plan), the DNREC Sediment and Stormwater Program (eNOI/NOT), Army Corp of Engineers, and/or DNREC Wetlands and Waterways Section prior to clearing and/or excavating ditch channels.

Contact: DNREC Drainage Program at (302) 855-1930.
Website: https://dnrec.delaware.gov/drainage-stormwater/
Tax Ditch Mapper: de.gov/taxditchmap
Tax Ditch guidelines: https://documents.dnrec.delaware.gov/swc/Drainage/Documents/Tax-Ditch-Land-Development-Guidelines.pdf

Stormwater Management

- Where the site and soil conditions allow, integrate runoff reduction techniques including infiltration basins, bioretention (rain gardens), filter strips, and pavers to encourage on-site stormwater infiltration and reduce runoff.

- For improved stormwater management, preserve existing trees, wetlands, and passive open space.

Plan review agency contact: Sussex Conservation District at (302) 856-2105 or (302) 856-7219. Website: https://www.sussexconservation.org/

General stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Vegetated Buffer Zones

Vegetated buffer zones placed adjacent to waterways and wetlands help improve water quality by reducing sediment and pollutants loads. Vegetated buffers are not equivalent to setbacks, as residential lots, walkways, and stormwater management facilities should not be contained within the vegetated buffer zone.

- It is recommended to increase the vegetated buffer zone to 100 feet from the edge of wetlands, sensitive habitats, and waterways across the site. Stormwater management areas should not be considered part of vegetated buffer zones.

- Vegetated buffer zones should be identified outside of the Limit of Disturbance on the engineering plans.

- Maintain vegetated buffer zones as native species meadows or forest.

- Vegetated buffer zones should be deeded as community open space and not contained within any lot lines. Signage should be installed at the edge and within the buffer zones to deter residents from encroaching into these common areas.

Contact: DNREC Wildlife Species Conservation & Research Program at (302) 735-3600.
Website: https://dnrec.delaware.gov/fish-wildlife/contact-information/

Water Quality
This site lies within the Nanticoke River Watershed. Surface water quality in this watershed does not meet Federal and/or State Water Quality Standards and a Pollution Control Strategy is in place for this watershed.

- Implement vegetated buffers with a width of at least 100 feet around all water features on or adjacent to the site.

- Reduce impervious surfaces on the project site by eliminating areas of impervious pavement and/or using pervious pavement where practicable. Break up large parking lots with planted islands.

- Reduce stormwater runoff by integrating infiltration basins, bioretention (rain gardens), filter strips, and by preserving existing trees, wetlands, and passive open space.

- Reduce the necessity for nutrient application by maintaining open space as meadow or forest planted exclusively with native plants. Native plants are well-suited to our climate and require limited maintenance.

Contact: DNREC Division of Watershed Stewardship's Watershed Assessment Section at (302) 739-9939. https://dnrec.alpha.delaware.gov/watershed-stewardship/

Sustainable Practices
- This site lies adjacent to the Greenwood Playground at Woodbridge Elementary School to the east. Consider adding a walking trail connection.

- To improve public safety and the wellbeing of future residents, follow all recommendations above regarding flooding.

- Avoid clearing of trees and consider planting stands of native trees. Native trees improve air, water, and soil quality. Planting and nurturing trees is also a nature-based solution to reducing the greenhouse gases that drive climate change. In addition, native trees have an increasingly important role in the survival of native birds and beneficial insects whose habitat is shrinking due to development and climate change.

- Use renewable energy infrastructure such as solar to reduce energy costs and further reduce pollution created from offsite generation. Grant funds and incentives are available for Delmarva Power customers through the DNREC Green Energy Fund, which includes several funding types through the state's major electric utilities (https://dnrec.delaware.gov/climate-coastal-energy/renewable/assistance/).

- Use efficient Energy Star rated products and materials in construction and redevelopment. Energy efficient appliances use less energy over time. This saves

consumers and businesses money, while also helping to reduce pollution from power generation.

- Use structural paint coatings that are low in Volatile Organic Compounds to help protect air quality. Air pollution from new construction is generated through the use of maintenance equipment, paints, and consumer products like roof coatings and primers.

- Use recycled materials, such as reclaimed asphalt pavement, to reduce heat island effects on paved surfaces, prevent landfill waste, and lower material costs.

Contact: DNREC Division of Climate, Coastal & Energy at (302) 735-3480.
Website: https://dnrec.delaware.gov/climate-coastal-energy/

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Population

- The county has a population density of 265.60 per square mile based on the US 2020 Census report; an increase from 2010 at 208.90 persons per square mile. The specific census block(s) the project is located on has a total population of 38, though, with development, this will undoubtedly change. The 19 adjacent blocks aggregated bring the area to a total population of 185.

FEMA National Risk Index

- The FEMA National Risk Index is an online mapping application that identifies communities most at risk to 18 natural hazards: Avalanche, Coastal Flooding, Cold Wave, Drought, Earthquake, Hal, Heat Wave, Hurricane, Ice Storm, Landslide, Lightning, Riverine Flooding, Strong Wind, Tornado, Tsunami, Volcanic Activity, Wildfire, and Winter Weather. The FEMA National Risk Index is calculated by multiplying the Expected Annual Loss times the Social Vulnerability and dividing that by the Community Resilience.

Expected Annual Loss
× Social Vulnerability
÷ Community Resilience
= Risk Index

- According to FEMA's National Risk Index, the parcel **is** considered **relatively moderate** for overall natural hazards risks.

- Community Resilience is a consequence reduction risk component and a community risk factor that represents the ability of a community to prepare for anticipated natural hazards, adapt to changing conditions and withstand/recover rapidly from disruptions. Social Vulnerability is a consequence-enhancing risk factor that represents the susceptibility of social groups to the adverse impacts of natural hazards.

- Its community resilience is rated as **relatively moderate** whereas its social vulnerability is rated as **relatively moderate.**

Renewable Energy Commitment

- Regarding energy use and consumption, the census tract utilizes **electricity** as the predominant fuel type for heating purposes.

- DEMA strongly encourages the use of renewable energies and high-efficiency appliances and utilities. Regarding utilities, DEMA suggests incorporating 90% series furnaces/HVAC systems; the closer to 99%, the better, as well as A/C units of 20 Seer or greater. DEMA recommends using tankless water heaters, and battery backup systems for sump pumps to reduce potential water damage from power failure. Lastly, DEMA encourages the integration of modern and emerging technologies, such as the potential for electric vehicles in garages/parking lots, green roofs or solar panels where applicable and allowable, and the like.

- In reference to the flood zones, DEMA strongly discourages construction of any type directly within, adjacent to or within proximity to a 100-year floodplain as water knows no bounds. If the homes are being constructed at flood level or below and a mortgage is obtained, an NFIP insurance policy is also required. Regardless of whether within or adjacent to a floodplain, should construction continue, we recommend utilizing additional mitigation strategies to reduce the risk from flooding. This could include, but isn't limited to, wet/dry floodproofing, elevating the home out of the flood plain, elevating mechanicals/HVAC/Electricity out of the flood waters, mass notification systems, large drainage systems (increased diameter pipes, ditches, basins, etc.) and other similar methods.

<u>Delaware State Housing Authority - Contact Rachel Alfano 302-739-4263</u>

- DSHA supports this proposal for 72-unit multifamily neighborhood consistent of garden-style apartment dwellings on 7.89 acres located East of Addix Avenue and South of Maryland Ave. in Greenwood. This proposal is consistent with State Strategy Investment levels 2.

- According to DSHA's Housing Reform Map, this project is in a Stable Area where diverse housing types should be supported. This market-rate proposal offers higher-density

housing options more responsive to household size and a more affordable option to first-time homebuyers. DSHA believes that this development will increase the diversity of housing types in the area and continue to foster balance and stability.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
Preliminary meetings with fire protection specialists are encouraged prior to formal submittal. Please call for appointment. Applications and brochures can be downloaded from our website: www.statefiremarshal.delaware.gov, technical services link, plan review, applications or brochures.

Following receipt of this letter and upon filing of an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason, therefore.

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,

David L. Edgell, AICP
Director, Office of State Planning Coordination

Attachments:
- DNREC Tax Ditch Map
- DNREC Tax Ditch Land Development Project Review Request Form

Greenwood Garden Apartments- Cart Branch TD



1/22/2025, 3:01:49 PM

Tax Ditch Channels

Tax Ditch Channel

DITCHPIPETD

Extent of Right-of-Way

Approx. Watershed Boundary

1:2,257

0 0.01 0.03 0.06 mi

0 0.02 0.04 0.09 km

Maxar, Microsoft, Esri Community Maps Contributors, Delaware FirstMap, VGIN, © OpenStreetMap, Microsoft, Esri, TomTom, Garmin, SafeGraph,

DNREC, Division of Watershed Stewardship, Drainage Program

These maps do not replace the official documents on file in the Prothonotary Office, and not to be used for engineering purposes

Division of Watershed Stewardship
Drainage Program
21309 Berlin Rd., Unit 6
Georgetown, DE 19947

Tax Ditch Land Development Project Review Request Form

Project Name: _____

Attach Site Plan of proposed request(s) and include all structures, easements, setbacks, etc. that make your proposal as requested necessary. Include and label existing tax ditch channel and rights-of-way for comparison.

Check out de.gov/taxditchmap to view tax ditch channels and rights-of-way from any web browser. To download the tax ditch GIS Feature Service layer to your own application, visit Delaware FirstMap. Don't forget to label all tax ditch features in all your plans!

Project Representative/Consultant Information:

Name(s): _____
Company: _____
Title(s): _____
Phone Number(s): _____
Email(s): _____

Owner(s) Contact Information:

Name: _____
Phone Number: _____
Email: _____

Authorized Signer(s) Contact Information (when applicable):

Name: _____
Title: _____
Phone Number: _____
Email: _____

For Internal Use Only
Date Received: _____
Tracking #: _____

Division of Watershed Stewardship
Drainage Program
21309 Berlin Rd., Unit 6
Georgetown, DE 19947

Property Information:

Tax Parcel(s) Affected: _____

Tax Ditch Organization(s) Affected: _____

Request(s) of / Proposed Impact(s) to Tax Ditch System (Check all that apply):

☐	Outfall/Discharge into Tax Ditch Channel(s)
☐	Pipe Crossing/Entrances in Tax Ditch Channel(s)
☐	Relocate/Eliminate Tax Ditch Channel(s)
☐	Reduce/Increase Tax Ditch Rights-of-Way
☐	Change Tax Ditch Watershed Boundary
☐	Alteration of Existing Tax Ditch Channel(s)
☐	Utility Crossing in Tax Ditch Channel
☐	Other Explain:

Based on the options selected above, additional information may be requested.

Please specify Tax Ditch Channel(s) affected, existing and requested tax ditch rights-of-way extents whenever applicable, using the space below. (REQUIRED)

Submit all forms to the DNREC Drainage Program
Via email: DNREC_drainage@delaware.gov
Subject Line: Tax Ditch- Land Development Request

For questions about this form please call the Tax Ditch Program at 302-855-1930.

For Internal Use Only
Date Received: _____
Tracking #: _____