STATE OF DELAWARE
OFFICE OF MANAGEMENT AND BUDGET
OFFICE OF STATE PLANNING COORDINATION

April 23, 2025

Stephen Davies
Apex Engineering, Inc.
27 West Market St
Newport, DE 19804

RE: PLUS review – 2025-03-01; Springhouse Preserve

Dear Mr. Davies:

Thank you for meeting with State agency planners on March 26th, 2025 to discuss Springhouse Preserve. According to the information received, you are seeking review of a proposed rezoning and site plan for a major residential development on 19.84 acres, transitioning from S (Suburban) to ST (Suburban Transition). The project includes 120 multifamily units, with 64 designated as affordable rentals and 56 as entry-level homeownership units.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State, and local regulations regarding this property. We also note that New Castle County is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the County.**

Strategies for State Policies and Spending

This project is located in Levels 1 & 2 investment area, which is consistent with the 2020 Strategies for State Policies and Spending.

Investment Level 1 reflects areas that are already developed in an urban or suburban fashion, where infrastructure is existing or readily available, and where future redevelopment or infill projects are expected and encouraged by State policy. Investment Level 2 reflects areas where growth is anticipated by local, county, and State plans in the near-term future. Because development in Level 1 and Level 2 is consistent with the 2020 Strategies for State Policies and Spending, the Office of State Planning Coordination supports this proposed rezoning and Site Plan.

Code Requirements/Agency Permitting Requirements

Department of Transportation – Contact Stephen Bayer 302-760-4834

- Any site access points onto State maintained roads must be designed in accordance with DelDOT's Development Coordination Manual, which is available at http://www.deldot.gov/Business/subdivisions/index.shtml?dc=changes.

- Pursuant to Section 1.3 of the Development Coordination Manual, a Pre-Submittal Meeting is required before plans are submitted for review. The form needed to request the meeting and guidance on what will be covered there and how to prepare for it is located at: https://www.deldot.gov/Business/subdivisions/pdfs/Meeting_Request_Form.pdf?08022017

- In terms of traffic analysis and based on the expected trip generation this project will require a Traffic Impact Study (TIS). Please coordinate with DelDOT Planning to complete this process and determine access and any required off-site improvements.

- Section 1.7 of the Development Coordination Manual addresses fees that are assessed for the review of development proposals. DelDOT anticipates collecting the Initial Stage Fee when the record plan is submitted for review and the Construction Stage Fee when construction plans are submitted for review.

- As necessary, in accordance with Section 3.2.5 and Figure 3.2.5-a of the Development Coordination Manual, DelDOT will require dedication of right-of-way along the site's frontage. By this regulation, this dedication is to provide a minimum of 30 feet of right-of-way from the physical centerline. The following right-of-way dedication note is required, "**An X-foot wide strip of right-of-way from the centerline is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- In accordance with Section 3.2.5.1.2 of the Development Coordination Manual, DelDOT will require the establishment of a 15-foot wide permanent easement across the property frontages on all State maintained roadways. The location of the easement shall be outside the limits of the ultimate right-of-way. The easement area can be used as part of the open space calculation for the site. The following note is required, "**A 15-foot wide permanent easement is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- Referring to Section 3.4.2.1 of the Development Coordination Manual, the following items, among other things, are required on the Record Plan:

  - A Traffic Generation Diagram. See Figure 3.4.2-a for the required format and content.

  - Notes identifying the type of off-site improvements, agreements (signal, letter) contributions and when the off-site improvements are warranted.

- Section 3.5.4.2 of the Development Coordination Manual addresses requirements for Shared Use Paths (SUP) and sidewalks. For projects in Level 1 Investment Areas, installation of paths or sidewalks along the frontage on State-maintained roads is required.

- In accordance with Section 3.8 of the Development Coordination Manual, storm water facilities, excluding filter strips and bioswales, shall be located a minimum of 20 feet from the ultimate State right-of-way along all frontage roads.

- In accordance with Section 5.2.9 of the Development Coordination Manual, the Auxiliary Lane Worksheet should be used to determine whether auxiliary lanes are warranted at the site entrances and how long those lanes should be. The worksheet can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.4 of the Development Coordination Manual, sight distance triangles are required and shall be established in accordance with American Association of State Highway and Transportation Officials (AASHTO) standards. A spreadsheet has been developed to assist with this task. It can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.14 of the Development Coordination Manual, all existing utilities must be shown on the plan and a utility relocation plan will be required for any utilities that need to be relocated.

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Staff from the Delaware Department of Natural Resources and Environmental Control (DNREC) reviewed the project submitted for PLUS review. The absence of comments regarding specific resources does not indicate that there are not additional constraints or environmental issues on site, nor does it indicate DNREC support of a project.

Stormwater Management
The project proposes greater than 5,000 square feet of land disturbing activities and will be subject to Delaware's *Sediment and Stormwater Regulations*.

- A Sediment and Stormwater Plan must be developed, then approved by the appropriate plan review agency, prior to any land disturbing activity taking place on the site. For this project, the plan review agency is the New Castle County Department of Land Use.

- Additionally, to address federal requirements, construction activities that exceed 1.0 acre of land disturbance require Construction General Permit coverage through submittal of an electronic Notice of Intent for Stormwater Discharges Associated with Construction Activity. This form must be submitted electronically https://enoi.dnrec.delaware.gov/, (select Construction Stormwater General Permit) to the DNREC Division of Watershed Stewardship, along with the $195 fee.

- Schedule a project application meeting with the appropriate plan review agency prior to moving forward with the stormwater and site design. As part of this process, you must submit a Stormwater Assessment Study.

Plan review agency contact: New Castle County Department of Land Use at (302) 395-5400.
Website: https://www.newcastlede.gov/2420/Land-Use

General Stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Special Flood Hazard Area
According to the newest Flood Insurance Rate Maps (FIRM), the eastern portion of this parcel is situated within a Special Flood Hazard Area, specifically within the mapped 100-year floodplain (1% annual chance of flooding). The Special Flood Hazard Area identified on the site lies within zone AE. In lands contained within the 100-year floodplain, the National Flood Insurance Program's floodplain management regulations must be enforced through the local floodplain ordinance, which can have higher standards. Although homes are proposed outside of the Special Flood Hazard Area (SFHA), some houses may still be required by lenders to purchase flood insurance, based on the proximity to the SFHA.

- The applicant must comply with the local floodplain ordinance and regulations applicable to development or construction within the 100-year floodplain. In determining the boundary of the floodplain, use the most recent FIRM maps available, which can be found at https://floodplanning.dnrec.delaware.gov/

Contact: DNREC Shoreline and Waterway Management Section at (302) 608-5500.
Website: https://dnrec.delaware.gov/watershed-stewardship/waterways/floodplains/

Wetlands and Waterways
Maps from the Statewide Wetlands Mapping Project indicate the potential presence of non-tidal wetlands in the central portion of the site. The application indicates that wetlands have been delineated. The application states that the project does not propose direct impacts to the wetlands.

State Requirements:

- If plans change and wetlands are disturbed, please contact the Wetlands and Waterways Section for more information on permitting requirements.

- Include all wetland boundaries on site plans.

State Contact: DNREC Wetlands and Waterways Section at (302) 739-9943.
Website: https://dnrec.delaware.gov/water/wetlands/

Federally-listed Threatened and Endangered Species – Bog Turtle
Habitat suitable for the bog turtle (*Glyptemys muhlenbergii*) may exist on the project site. The bog turtle is protected under the Federal Endangered Species Act.

- Consult with the U.S. Fish and Wildlife Service to determine what permits or surveys may be required. Projects can be submitted through the Information for Planning and Consultation tool through the U.S. Fish and Wildlife Service at https://ecos.fws.gov/ipac/.

- To ensure that the project will not impact bog turtles or their habitat, a Phase I survey for bog turtle habitat must be conducted on the entire project parcel(s) prior to any land disturbing activity taking place. Phase I surveys can be conducted any time of year when ice and/or snow cover is not present.

- If potential bog turtle habitat is found during Phase I surveys, you are required to either:

    1. Completely avoid all direct and indirect project impacts to the wetland and implement a 300-foot buffer of the wetland, in consultation with the U.S. Fish and Wildlife Service and DNREC Division of Fish and Wildlife; **or**

    2. Have surveys (Phase II and/or trapping) conducted to determine if bog turtles are present. In accordance with Delaware's bog turtle site survey procedures, surveys must be conducted by a qualified bog turtle surveyor between April 15 and June 15. Please note that surveys may confirm presence of turtles, but they cannot

confirm absence and guidance to minimize impact to the habitat may be applicable even if bog turtles are not found during surveys

- All bog turtle surveys must be conducted by a Delaware approved bog turtle surveyor.

- Please contact the DNREC Division of Fish and Wildlife Species Conservation and Research Program to obtain a list of professionals who are qualified to conduct Phase I and II surveys.

Federal Contact: U.S. Fish and Wildlife Service, Chesapeake Bay Ecological Services Field Office at (410) 573-4599.
Website: https://www.fws.gov/office/chesapeake-bay-ecological-services

State Contact: DNREC Division of Fish and Wildlife, Species Conservation and Research Program at (302) 735-3600.
Website: https://dnrec.delaware.gov/fish-wildlife/conservation/

Wastewater Disposal Systems – Large Systems
For wastewater conveyance offsite by way of a new sewer connection, flow rates exceeding 2,500 gallons of liquid waste per day will require a Wastewater Pollution Collection and Conveyance (WPCC) permit from the Commercial and Government Services section.

Contact: DNREC Commercial and Government Services Section at (302) 739-9948.
Website: https://dnrec.delaware.gov/water/commercial-government/

Electric Vehicle Charging Requirements
Electric vehicle charging infrastructure is now required for all residential dwellings in Delaware (see 80 Del. Laws, c. 145 § 8001- § 8006) for which:

1. A building permit is issued on or after January 1, 2024 (single family), or
2. The final site plan is approved on or after January 1, 2025 (multi-family).

Requirements are summarized below. Consult the Delaware Code directly for further details.

Multi-family Dwellings, effective 2025:
- The developer of a multi-family residential dwelling shall install electric vehicle parking spaces, where at least 5% of the total parking spaces for the multi-family residential dwelling must be electric vehicle capable parking spaces.
- In addition, a developer of a multi-family residential dwelling shall provide at least one electric vehicle charging infrastructure parking space in an area available for use by all residents of the multi-family residential dwelling (example: community centers).

- Construction documents must indicate the location of proposed electric vehicle charging infrastructure parking spaces and electric vehicle capable parking spaces.

- Parking space dimensions must comply with the county or municipal building code applicable to the multi-family residential dwelling.

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Proposed Project Parcel Flood Concern

- The vast majority of the parcel is located within an area of **Minimal Flood Concern of 1000 years or greater**. However, it does appear that a flood zone exists to the eastern most portion of the parcel, which is identified as a 100-year flood event or a 1% annual chance flood hazard special flood hazard area (SFHA) known as Flood Zone AE.



Parcel Status within County Evacuation Zone Location

- The parcel is not yet located within a New Castle County Evacuation Zone.

Parcel Status within the 10-mile Emergency Planning Zone (EPZ) for the Salem Nuclear Power Plant

- The parcel **is not** located within the 10-mile EPZ for the Salem Nuclear Power Plant.

State Historic Preservation Office – Contact Carlton Hall 302-736-7400

- There is a known documented building on the southern portion of parcel# 080370037 that was determined eligible for NR listing known as the McKennan-Klair House N01250.

- For the proposed project, it appears that at least one of the supporting structures (the early 19th century, frame, two-story vernacular barn) is proposed for demolition and

there will be significant alterations to the main house based on the plans. The outbuildings were included with the McKennan-Klair House in the 1987 determination of eligibility. The Delaware SHPO recommends avoiding demolition of the main house or any contributing structures of the McKennan-Klair House property. Any alteration or adaptive reuse of these buildings should be carried out in keeping with the Secretary of the Interior's Standards for the Treatment of Historic Properties.

- The State Historic Preservation Office received the archaeological report that declared the site on the parcel from the previous survey performed on the site and it is in their records.

- Note, however, that if the project and therefore disposition of the barn are subject to review by the New Castle County Historic Review Board, that body will advise as to any required next steps. Additionally, if there is federal involvement, in the form of licenses, permits, or funds, the federal agency, often through its client, is responsible for complying with Section 106 of the National Historic Preservation Act (36 CFR 800), which requires the agency and the applicant to consider their project's effects on any known or potential cultural or historic resources**.** It is the understanding of the DESHPO that there remains some question as to whether or not a permit from the U.S. Army Corps of Engineers (USACE) will be needed. Should a permit be required, the applicant should engage the USACE's cultural resource staff as soon as possible to begin from Section 106 consultation. For further information on the Section 106 process please review the Advisory Council on Historic Preservation's website at: www.achp.gov

  If there are any questions, inquiries, or concerns, feel free to contact the Delaware State Historic Preservation Office for assistance at 302-736-7400.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
This document is for information purposes only and does not constitute any type of approval from the Delaware State Fire Marshal's Office.

- This Agency has no objection to the re-zoning request.

At the time of formal submittal, the applicant shall provide; completed application, fee, and three sets of plans depicting the following in accordance with the Delaware State Fire Prevention Regulation (DSFPR):

Fire Protection Water Requirements:

- Water distribution system capable of delivering at least 1000 gpm for 1-hour duration, at 20-psi residual pressure is required. Fire hydrants with 800 feet spacing on centers. (Assembly, Business, and Townhouses)

- One- and Two-Family dwellings (townhouses) are required by law to offer the homeowner an automatic sprinkler system, therefore infrastructure should accommodate water needs.

- Where a water distribution system is proposed for the site, the infrastructure for fire protection water shall be provided, including the size of water mains for fire hydrants and sprinkler systems.

Fire Protection Features:

- All structures over 10,000 Sq. Ft. aggregate will require automatic sprinkler protection installed.

- Buildings greater than 10,000 sq. ft, 3-stories or more, over 35 feet, or classified as High Hazard, are required to meet fire lane marking requirements

- Show Fire Department Connection location (Must be within 300 feet of fire hydrant), and detail as shown in the DSFPR.

- Show Fire Lanes and Sign Detail as shown in DSFPR

- For townhouse buildings, provide a section / detail and the UL design number of the 2-hour fire rated separation wall on the Site plan.

Accessibility

- All premises, which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads, and fire lanes so that all buildings on the premises are accessible to fire apparatus. This means that the access road to the subdivision from Limestone Rd, Concord Dr, and Ascension Dr must be constructed so fire department apparatus may negotiate it.

- Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.

- Any dead-end road more than 300 feet in length shall be provided with a turn-around or cul-de-sac arranged such that fire apparatus will be able to turn around by making not more than one backing maneuver. The minimum paved radius of the cul-de-sac shall be 38 feet. The dimensions of the cul-de-sac or turn-around shall be shown on the final plans. Also, please be advised that parking is prohibited in the cul-de-sac or turn around.

- The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.

- The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.

Gas Piping and System Information:

- Provide type of fuel proposed and show locations of bulk containers on plan.

Required Notes:

- Provide a note on the final plans submitted for review to read "All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations."
- Proposed Use
- Alpha or Numerical Labels for each building/unit for sites with multiple buildings/units
- Square footage of each structure (Total of all Floors)
- National Fire Protection Association (NFPA) Construction Type
- Maximum Height of Buildings (including number of stories)
- Townhouse 2-hr separation wall details shall be shown on site plans
- Note indicating if building is to be sprinklered
- Name of Water Provider
- Letter from Water Provider approving the system layout
- Provide Lock Box Note (as detailed in DSFPR) if Building is to be sprinklered
- Provide Road Names, even for County Roads

Recommendations/Additional Information

This section includes a list of site-specific suggestions that are intended to enhance the project. These suggestions have been generated by the State Agencies based on their expertise and subject area knowledge. **These suggestions do not represent State code requirements.** They are offered here in order to provide proactive ideas to help the applicant enhance the site design, and it is hoped **(but in no way required)** that the applicant will open a dialogue with the relevant agencies to discuss how these suggestions can benefit the project.

Department of Transportation – Contact Stephen Bayer 302-760-4834

- The applicant should expect a requirement that all PLUS and Technical Advisory Committee (TAC) comments be addressed prior to submitting plans for review.

- Please be advised that the Standard General Notes have been updated and posted to the DelDOT website. Please begin using the new versions and look for the revision dates of March 21, 2019 and March 16, 2021. The notes can be found at https://www.deldot.gov/Business/subdivisions/

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Stormwater Management

- Where the site and soil conditions allow, integrate runoff reduction techniques including infiltration basins, bioretention (rain gardens), filter strips, and pavers to encourage on-site stormwater infiltration and reduce runoff.

- For improved stormwater management, preserve existing trees, wetlands, and passive open space.

Plan review agency contact: New Castle County Department of Land Use at (302) 395-5400.
Website: https://www.newcastlede.gov/2420/Land-Use

General stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Drainage

- All existing drainage ditches on the property should be evaluated for function and cleaned, if needed, prior to the construction of the project.

- Environmental permits or exemptions may be required by the County Conservation District (Standard Plan), the DNREC Sediment and Stormwater Program (eNOI/NOT), Army Corp of Engineers, and/or DNREC Wetlands and Waterways Section prior to clearing and/or excavating ditch channels.

- All precautions should be taken to ensure the project does not hinder any off-site drainage upstream of the project or create any off-site drainage problems downstream by the release of on-site storm water.

- Any area designated as a drainage/utility easement should be open space and not owned by the individual landowners.

- Any drainage/utility easement should not possess structures such as decks, buildings, sheds, kennels, or fences within the drainage easement to allow for future drainage maintenance. Trees and shrubs planted within a drainage/utility easement should be spaced to allow for drainage maintenance at maturity.

Contact: DNREC Drainage Program at (302) 855-1930.
Website: https://dnrec.delaware.gov/drainage-stormwater/

Forested Wetlands and Vegetated Buffer Zones
Maps from the Statewide Wetlands Mapping Project indicate the potential presence of forested wetlands on the central portion of the site. This habitat type is known to support an array of plants and animals, most notably wetland dependent species such as amphibians.

To reduce impacts to these species, the following is recommended:

- Do not disturb forested wetlands. Maintain an upland buffer of at least 100 feet along all wetlands, waterways, and sensitive habitats, including those containing existing forest or natural vegetative cover.

- Vegetated buffer zones should be identified outside of the Limit of Disturbance on the engineering plans.

- Maintain vegetated buffer zones as native species meadows or forest.

- Vegetated buffer zones should be deeded as community open space and not contained within any lot lines. Signage should be installed at the edge and within the buffer zones to deter residents from encroaching into these common areas.

- Maintain habitat connections to undeveloped open space, which are especially important for species movement across the landscape.

Contact: DNREC Division of Fish and Wildlife, Species Conservation and Research Program at (302) 735-3600. Website: https://dnrec.delaware.gov/fish-wildlife/conservation/

Federally-listed Threatened and Endangered Species – Bog Turtle

- Until further agency guidance is provided, limit disturbance (including noise) of forest areas, wetlands, meadows, streams, etc.

Federal Contact: U.S. Fish and Wildlife Service, Chesapeake Bay Ecological Services Field Office at (410) 573-4599.

Website: https://www.fws.gov/office/chesapeake-bay-ecological-services

State Contact: DNREC Division of Fish and Wildlife, Species Conservation and Research Program at (302) 735-3600.
Website: https://dnrec.delaware.gov/fish-wildlife/conservation/

Sustainable Practices

- Incorporate nonmotorized connectivity and install bicycle racks and covered bike storage where feasible to help facilitate non-vehicular travel modes.

- Use renewable energy infrastructure such as solar or geothermal to reduce energy costs and further reduce pollution created from offsite generation. Grant funds and incentives are available for Delmarva Power customers through the DNREC Green Energy Fund, which includes several funding types through the state's major electric utilities (https://dnrec.delaware.gov/climate-coastal-energy/renewable/assistance/).

- Consider planting select areas with native trees. Native trees improve air, water, and soil quality. Planting and nurturing trees is also a nature-based solution to reducing the greenhouse gases that drive climate change. In addition, native trees have an increasingly important role in the survival of native birds and beneficial insects whose habitat is shrinking due to development and climate change.

- Consider planting select areas with meadow comprised of native species. Native plants are well-suited to our climate and require limited maintenance. Mowing in these areas should not occur between April 1st to July 31st to reduce impacts to nesting birds and other wildlife species that utilize meadows and grasslands for breeding habitat.

- Use efficient Energy Star rated products and materials in construction and redevelopment. Energy efficient appliances use less energy over time. This saves consumers and businesses money, while also helping to reduce pollution from power generation.

- Use structural paint coatings that are low in Volatile Organic Compounds to help protect air quality. Air pollution from new construction is generated through the use of maintenance equipment, paints, and consumer products like roof coatings and primers.

- Use recycled materials, such as reclaimed asphalt pavement, to reduce heat island effects on paved surfaces, prevent landfill waste, and lower material costs.

- Include space for recycling dumpsters within the preliminary site design stage. These can be placed adjacent to trash dumpsters.

Contact: DNREC Division of Climate, Coastal & Energy at (302) 735-3480.
Website: https://dnrec.delaware.gov/climate-coastal-energy/

Delaware Emergency Management Agency – Contact Phillip Cane 302-659-2325

Population

- The county has a population density of 1,321.50 per square mile based on the US 2020 Census report; an increase from 2010 at 1,241.00 persons per square mile. The specific census block(s) the project is located on has a total population of 747, though, with development, this will undoubtedly change. The 15 adjacent blocks aggregated bring the area to a total population of 2866.

FEMA National Risk Index

- The FEMA National Risk Index is an online mapping application that identifies communities most at risk to 18 natural hazards: Avalanche, Coastal Flooding, Cold Wave, Drought, Earthquake, Hal, Heat Wave, Hurricane, Ice Storm, Landslide, Lightning, Riverine Flooding, Strong Wind, Tornado, Tsunami, Volcanic Activity, Wildfire, and Winter Weather. The FEMA National Risk Index is calculated by multiplying the Expected Annual Loss times the Social Vulnerability and dividing that by the Community Resilience.



- According to FEMA's National Risk Index, the parcel is considered relatively low for overall natural hazards risks.

- Community Resilience is a consequence reduction risk component and a community risk factor that represents the ability of a community to prepare for anticipated natural hazards, adapt to changing conditions and withstand/recover rapidly from disruptions. Social Vulnerability is a consequence-enhancing risk factor that represents the susceptibility of social groups to the adverse impacts of natural hazards.

- Its community resilience is rated as relatively high whereas its social vulnerability is rated as very low.

Renewable Energy Commitment

- Regarding energy use and consumption, the census tract utilizes utility/natural gas as the predominant fuel type for heating purposes.

- DEMA strongly encourages the use of renewable energies and high-efficiency appliances and utilities. Regarding utilities, DEMA suggests incorporating 90% series furnaces/HVAC systems; the closer to 99%, the better, as well as A/C units of 20 Seer or greater. DEMA recommends using tankless water heaters, and battery backup systems for sump pumps to reduce potential water damage from power failure. Lastly, DEMA encourages the integration of modern and emerging technologies, such as the potential for electric vehicles in garages/parking lots, green roofs or solar panels where applicable and allowable, and the like.

Delaware State Housing Authority - Contact Alex Modeas 952-255-9579 ext. 251

- DSHA supports this proposal for 120-unit multifamily mixed residential development on 19.84 acres located at 3401 Limestone Road in Wilmington. This proposal is consistent with State Strategy Investment levels 1 & 2.

- According to DSHA's Housing Reform Map, this project is in an Area of Opportunity. This map shows the distribution of affordable housing throughout the state. We encourage the creation of affordable housing in Areas of Opportunity which contain little to none. These areas also offer economic opportunity, high performing schools, and supportive infrastructure that help household succeed.

- Following that, we do encourage the proposal to add bike paths to create easy access and connectivity to its surroundings.

If you have questions or would like more information on the above recommendations, please feel free to e-mail at Rachel.Alfano@Delaware.gov.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
Preliminary meetings with fire protection specialists are encouraged prior to formal submittal. Please call for appointment. Applications and brochures can be downloaded from our website: www.statefiremarshal.delaware.gov, technical services link, plan review, applications or brochures.
The proposed business occupancy could create some unique code issues. I would suggest a pre-application meeting with our staff in the New Castle office at MacArthur Dr.

Following receipt of this letter and upon filing of an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning

Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason, therefore.

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,



David L. Edgell, AICP
Director, Office of State Planning Coordination