STATE OF DELAWARE
OFFICE OF MANAGEMENT AND BUDGET
OFFICE OF STATE PLANNING COORDINATION

November 18, 2025

Atwell LLC
Attn: John Mascari
1 Park Ave,
Milford, Delaware 19963

RE: PLUS review – 2025-10-07 Boyd's Corner Preserve

Dear Mr. Mascari:

Thank you for meeting with State agency planners on October 29th, 2025 to discuss Boyd's Corner Preserve. According to the information received, you are seeking review of a proposed residential subdivision consisting of 165 detached single-family dwelling units on 90.6 acres.

Please note that changes to the plan, other than those suggested in this letter, could result in additional comments from the State. Additionally, these comments reflect only issues that are the responsibility of the agencies represented at the meeting. **The developers will also need to comply with any Federal, State, and local regulations regarding this property. We also note that New Castle County is the governing authority over this land, the developers will need to comply with any and all regulations/restrictions set forth by the County.**

Strategies for State Policies and Spending

This project is located in a Level 1 and Level 2 investment area, which is consistent with the 2020 Strategies for State Policies and Spending.

Investment Level 1 reflects areas that are already developed in an urban or suburban fashion, where infrastructure exists or readily available, and where future redevelopment or infill projects are expected and encouraged by State policy. Investment Level 2 reflects areas where growth is anticipated by local, county, and State plans in the near-term future. Because development in Levels 1 and 2 is consistent with the 2020 Strategies for State Policies and Spending, the Office of State Planning Coordination supports this subdivision.

Code Requirements/Agency Permitting Requirements

Department of Transportation – Contact Stephen Bayer 302-760-4834

- Any site access points onto State maintained roads must be designed in accordance with DelDOT's Development Coordination Manual, which is available at http://www.deldot.gov/Business/subdivisions/index.shtml?dc=changes.

- Pursuant to Section 1.3 of the Development Coordination Manual, a Pre-Submittal Meeting is required before plans are submitted for review. The form needed to request the meeting and guidance on what will be covered there and how to prepare for it is located at https://www.deldot.gov/Business/subdivisions/pdfs/Meeting_Request_Form.pdf?08022017.

- In terms of traffic analysis and based on the expected trip generation this project would ordinarily require a Traffic Impact Study (TIS). However, this location is in the Southern New Castle County Transportation Improvement District (TID). Traffic analysis for the project will be satisfied by paying the applicable fee as calculated in the TID program.

- Section 1.7 of the Development Coordination Manual addresses fees that are assessed for the review of development proposals. DelDOT anticipates collecting the Initial Stage Fee when the record plan is submitted for review and the Construction Stage Fee when construction plans are submitted for review.

- As necessary, in accordance with Section 3.2.5 and Figure 3.2.5-a of the Development Coordination Manual, DelDOT will require dedication of right-of-way along the site's frontage with Boyd's Corner Road. By this regulation, this dedication is to provide a minimum of 40 feet of right-of-way from the physical centerline. The following right-of-way dedication note is required, "**An X-foot wide strip of right-of-way from the centerline is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- In accordance with Section 3.2.5.1.2 of the Development Coordination Manual, DelDOT will require the establishment of a 15-foot wide permanent easement across the property frontages on all State maintained roadways. The location of the easement shall be outside the limits of the ultimate right-of-way. The easement area can be used as part of the open space calculation for the site. The following note is required, "**A 15-foot wide permanent easement is hereby dedicated in fee simple to the State of Delaware, acting by and through the Delaware Department of Transportation."**

- Referring to Section 3.4.2.1 of the Development Coordination Manual, the following items, among other things, are required on the Record Plan:

    - A Traffic Generation Diagram. See Figure 3.4.2-a for the required format and content.

    - Notes identifying the type of off-site improvements, agreements (signal, letter) contributions and when the off-site improvements are warranted.

- Section 3.5.4.2 of the Development Coordination Manual addresses requirements for Shared Use Paths (SUP) and sidewalks. For projects in Level 2 Investment Areas, installation of paths or sidewalks along the frontage on State-maintained roads is required.

- In accordance with Section 3.8 of the Development Coordination Manual, storm water facilities, excluding filter strips and bioswales, shall be located a minimum of 20 feet from the ultimate State right-of-way along all frontage roads.

- In accordance with Section 5.2.9 of the Development Coordination Manual, the Auxiliary Lane Worksheet should be used to determine whether auxiliary lanes are warranted at the site entrances and how long those lanes should be. The worksheet can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.4 of the Development Coordination Manual, sight distance triangles are required and shall be established in accordance with American Association of State Highway and Transportation Officials (AASHTO) standards. A spreadsheet has been developed to assist with this task. It can be found at http://www.deldot.gov/Business/subdivisions/index.shtml.

- In accordance with Section 5.14 of the Development Coordination Manual, all existing utilities must be shown on the plan and a utility relocation plan will be required for any utilities that need to be relocated.

- Because the proposed development is to be constructed in the proximity of a road with a functional classification of principal arterial, freeway or interstate, (specifically US Rt. 301) the developer will be required to perform a noise analysis in accordance with DelDOT's Noise Policy, found in Section 3.6 of the Development Coordination Manual. Noise abatement measures may be required based on that analysis.

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Staff from the Delaware Department of Natural Resources and Environmental Control (DNREC) reviewed the project submitted for PLUS review. The absence of comments regarding specific resources does not indicate that there are not additional constraints or environmental issues on site, nor does it indicate DNREC support of a project.

Stormwater Management

The project proposes greater than 5,000 square feet of land disturbing activities and will be subject to Delaware's *Sediment and Stormwater Regulations*.

- A Sediment and Stormwater Plan must be developed, then approved by the appropriate plan review agency, prior to any land disturbing activity taking place on the site. For this project, the plan review agency is the New Castle County Department of Land Use.

- Additionally, to address federal requirements, construction activities that exceed 1.0 acre of land disturbance require Construction General Permit coverage through submittal of an electronic Notice of Intent for Stormwater Discharges Associated with Construction Activity. This form must be submitted electronically https://enoi.dnrec.delaware.gov/, (select Construction Stormwater General Permit) to the DNREC Division of Watershed Stewardship, along with the $195 fee.

- Schedule a project application meeting with the appropriate plan review agency prior to moving forward with the stormwater and site design. As part of this process, you must submit a Stormwater Assessment Study.

  Plan review agency contact: New Castle County Department of Land Use at (302) 395-5400. Website: https://www.newcastlede.gov/2420/Land-Use

  General Stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921. E-mail: DNREC.Stormwater@delaware.gov.
  Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Hydrologic Soils Group

Hydrologic Soil Group C and D, poorly drained soils, have been identified in the northern, central, and southern portions of the site. These soil types could worsen existing drainage issues if present and are typically not conducive to utilizing infiltration stormwater Best

Management Practices such as bioretention and infiltration basins. These practices must meet minimum infiltration requirements.

- Any stormwater Best Management Practices that propose the use of infiltration or natural recharge shall include a soils investigation.

Contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Water Resources Protection Area and Excellent Groundwater Recharge Area

A Water Resource Protection Area is located on the eastern portion of the site. These are the delineated areas which contribute water to a public water supply. These areas have soils that are conducive to water infiltrating downward from surface water into groundwater. Preservation of these areas is important for replenishing groundwater supplies and ensuring drinking water for future generations.

- Applicants must comply with local ordinances for Water Resource Protection Areas which normally have requirements limiting the amount of impervious cover and types of land uses that can occur within these areas.

- The applicant must comply with all county and municipal requirements for construction and uses in Excellent Groundwater Recharge Areas.

Contact: DNREC Source Water Assessment and Protection Program at (302) 739-9948.
Website: https://dnrec.delaware.gov/water/supply/ground-water-protection/

Wastewater Disposal Systems – Large Systems

For wastewater conveyance offsite by way of a new sewer connection, flow rates exceeding 2,500 gallons of liquid waste per day will require a Wastewater Pollution Collection and Conveyance (WPCC) permit from the Commercial and Government Services section.

Contact: DNREC Commercial and Government Services Section at (302) 739-9948.
Website: https://dnrec.delaware.gov/water/commercial-government/

Wetlands and Waterways

Maps from the Statewide Wetlands Mapping Project indicate the potential presence of non-tidal wetlands in the southwestern portion of the site. The application indicates that wetlands have been delineated. According to the application, the U.S. Army Corps of Engineers sign-off is

completed. The application states that the project does not propose direct impacts to the wetlands.

State Requirements:

- If plans change and wetlands are disturbed, please contact the Wetlands and Waterways Section for more information on permitting requirements.

State Contact: DNREC Wetlands and Waterways Section at (302) 739-9943.
Website: https://dnrec.delaware.gov/water/wetlands/

Electric Vehicle Charging Requirements

Electric vehicle charging infrastructure is now required for all residential dwellings in Delaware (see 80 Del. Laws, c. 145 § 8001- § 8006) for which:

1. A building permit is issued on or after January 1, 2024 (single family), or
2. The final site plan is approved on or after January 1, 2025 (multi-family).

Requirements are summarized below. Consult the Delaware Code directly for further details.

Single-family Dwellings, effective 2024:

- The developer of a single-family residential dwelling shall install at least one electric vehicle capable parking space at each single-family residential dwelling constructed.

- If the single-family residential dwelling does not have an attached or detached garage, an electric vehicle capable parking space must be provided in the driveway, assigned parking space for the dwelling, or at an unassigned non-street residential parking space constructed as part of the project.

Air Quality – Particulate Emissions

Particulate emissions are regulated by DNREC's Division of Air Quality. To control particulate emissions from construction and materials handling operations, the following is required:

- The applicant must use dust suppressants and other measures during demolition activities, grading, land clearing, excavation of non-paved roads, material movement or storage, and sandblasting activities.

Contact: DNREC Division of Air Quality at (302) 739-9402.
Website: https://dnrec.delaware.gov/air/permitting/

State Historic Preservation Office – Contact Carlton Hall 302-736-7400

- There are no known archaeological sites or known National Register-listed or eligible properties on the parcel. A survey was conducted, and it was almost entirely a pedestrian survey, with excavation confined to the center of the site. There is a precontact and historic component to this site. There is the historic agricultural complex in the center of the parcel with some structures being demolished over time. Our office is recommending an architectural survey and recent photographs for evaluation of the surviving structures. The project has a high potential for precontact and historic archaeological resources.

- Our office highly recommends an archaeological survey prior to any ground disturbance activities. Abandoned or unmarked family cemeteries are very common in Delaware, especially on historic farm sites, rural areas, or open space lands. Agricultural complexes also carry an increased potential for family burial plots. Therefore, if any project or development proceeds, the developer should be aware of the Unmarked Human Burials and Human Skeletal Remains Law (Del. C. Title 7, Ch. 54).

- If there are any questions, inquiries, or concerns, feel free to contact the Delaware State Historic Preservation Office for assistance at 302-736-7400.

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
This document is for information purposes only and does not constitute any type of approval from the Delaware State Fire Marshal's Office.

At the time of formal submittal, the applicant shall provide completed application, fee, and three sets of plans depicting the following in accordance with the Delaware State Fire Prevention Regulation (DSFPR):

Fire Protection Water Requirements:

- Where a water distribution system is proposed for single-family dwellings, it shall be capable of delivering at least 500 gpm for 1-hour duration, at 20-psi residual pressure. Fire hydrants with 800 feet spacing on centers are required. (One & Two- Family Dwelling)

- One- and Two-Family dwellings are required by law to offer the homeowner an automatic sprinkler system, therefore infrastructure should accommodate water needs.

- Where a water distribution system is proposed for the site, the infrastructure for fire protection water shall be provided, including the size of water mains for fire hydrants and sprinkler systems.

Accessibility

- All premises, which the fire department may be called upon to protect in case of fire, and which are not readily accessible from public roads, shall be provided with suitable gates and access roads, and fire lanes so that all buildings on the premises are accessible to fire apparatus. This means that the access road to the subdivision from Boyds Corner Road must be constructed so fire department apparatus may negotiate it.

- Fire department access shall be provided in such a manner so that fire apparatus will be able to locate within 100 ft. of the front door.

- Any dead-end road more than 300 feet in length shall be provided with a turn-around or cul-de-sac arranged such that fire apparatus will be able to turn around by making not more than one backing maneuver. The minimum paved radius of the cul-de-sac shall be 38 feet. The dimensions of the cul-de-sac or turn-around shall be shown on the final plans. Also, please be advised that parking is prohibited in the cul-de-sac or turn around.

- The use of speed bumps or other methods of traffic speed reduction must be in accordance with Department of Transportation requirements.

- The local Fire Chief, prior to any submission to our Agency, shall approve in writing the use of gates that limit fire department access into and out of the development or property.

Gas Piping and System Information:

- Provide type of fuel proposed and show locations of bulk containers on plan.

Required Notes:

- Provide a note on the final plans submitted for review to read “All fire lanes, fire hydrants, and fire department connections shall be marked in accordance with the Delaware State Fire Prevention Regulations”

- Proposed Use

- Alpha or Numerical Labels for each building/unit for sites with multiple buildings/units

- Square footage of each structure (Total of all Floors)

- National Fire Protection Association (NFPA) Construction Type

- Maximum Height of Buildings (including number of stories)

- Note indicating if building is to be sprinklered
- Name of Water Provider
- Letter from Water Provider approving the system layout
- Provide Lock Box Note (as detailed in DSFPR) if Building is to be sprinklered
- Provide Road Names, even for County Roads

Recommendations/Additional Information

This section includes a list of site-specific suggestions that are intended to enhance the project. These suggestions have been generated by the State Agencies based on their expertise and subject area knowledge. **These suggestions do not represent State code requirements.** They are offered here in order to provide proactive ideas to help the applicant enhance the site design, and it is hoped **(but in no way required)** that the applicant will open a dialogue with the relevant agencies to discuss how these suggestions can benefit the project.

Department of Transportation – Contact Stephen Bayer 302-760-4834

- The applicant should expect a requirement that all PLUS and Technical Advisory Committee (TAC) comments be addressed prior to submitting plans for review.
- Please be advised that the Standard General Notes have been updated and posted to the DelDOT website. Please begin using the new versions and look for the revision dates of March 21, 2019 and March 16, 2021. The notes can be found at https://www.deldot.gov/Business/subdivisions/

Department of Natural Resources and Environmental Control – Contact Beth Krumrine 302-735-3480

Water Resources Protection Area and Excellent Groundwater Recharge Area

- For Excellent Groundwater Recharge Areas, limit impervious surfaces to no more than 20% of the entire area designated as having excellent recharge.

Contact: DNREC Source Water Assessment and Protection Program at (302) 739-9948.
Website: https://dnrec.delaware.gov/water/supply/ground-water-protection/

Stormwater Management

- Where the site and soil conditions allow, integrate runoff reduction techniques including infiltration basins, bioretention (rain gardens), filter strips, and pavers to encourage on-site stormwater infiltration and reduce runoff.

- For improved stormwater management, preserve existing trees, wetlands, and passive open space.

Plan review agency contact: New Castle County Department of Land Use at (302) 395-5400.
Website: https://www.newcastlede.gov/2420/Land-Use

General stormwater contact: DNREC Sediment and Stormwater Program at (302) 739-9921.
E-mail: DNREC.Stormwater@delaware.gov.
Website: https://dnrec.delaware.gov/watershed-stewardship/sediment-stormwater/

Water Quality

This site lies within the Appoquinimink River Watershed. Surface water quality in this watershed does not meet Federal and/or State Water Quality Standards and a Pollution Control Strategy is in place for this watershed.

- Reduce impervious surfaces on the project site by eliminating areas of impervious pavement and/or using pervious pavement where practicable.

- Reduce stormwater runoff by integrating infiltration basins, bioretention (rain gardens), filter strips, and by preserving existing trees, wetlands, and passive open space.

- Reduce the necessity for nutrient application by maintaining open space as meadow or forest planted exclusively with native plants. Native plants are well-suited to our climate and require limited maintenance.

Contact: DNREC Division of Watershed Stewardship's Watershed Assessment Section at (302) 739-9939. Website: https://dnrec.alpha.delaware.gov/watershed-stewardship/

Forested Wetlands and Vegetated Buffer Zones

Maps from the Statewide Wetlands Mapping Project indicate the potential presence of forested wetlands on the southwestern portion of the site. This habitat type is known to support an array of plants and animals, most notably wetland dependent species such as amphibians.

- Do not disturb forested wetlands. Maintain an upland buffer of at least 100 feet along all wetlands, waterways, and sensitive habitats, including those containing existing forest or natural vegetative cover.

- Vegetated buffer zones should be identified outside of the Limit of Disturbance on the engineering plans.

- Maintain vegetated buffer zones as native species meadows or forest.

- Vegetated buffer zones should be deeded as community open space and not contained within any lot lines. Signage should be installed at the edge and within the buffer zones to deter residents from encroaching into these common areas.

- Maintain habitat connections to undeveloped open space, which are especially important for species movement across the landscape.

Contact: DNREC Division of Fish and Wildlife, Species Conservation and Research Program at (302) 735-3600. Website: https://dnrec.delaware.gov/fish-wildlife/conservation/

Air Quality – Design to Minimize Mobile Source Emissions
Mobile sources include a variety of motor vehicles and mobile equipment that generate air emissions, such as ozone, particle pollution, and air toxics. The DNREC Mobile Sources Control Program reduces motor vehicle-related pollution from both on-road vehicles and non-road vehicles.

- This site lies within New Castle County. Ambient air quality in this area may not meet Federal Air Quality Standards.

- Consider designing the project to connect to local pedestrian and bicycle networks. Designing for travel alternatives has the potential to minimize the overall tailpipe emissions associated with the use of this site.

- Consider designing the project for low maintenance green spaces. Designing green spaces to be less dependent on gas-powered lawn and garden equipment has the potential to minimize emissions associated with the on-going maintenance of this site.

Contact: DNREC Division of Air Quality's Mobile Sources Program at (302) 739-9402.

Website: https://dnrec.delaware.gov/air/mobile-sources/

Sustainable Practices

- Incorporate nonmotorized connectivity and install bicycle racks where feasible to help facilitate non-vehicular travel modes.

- Offer the option to install solar or geothermal systems for each home. This allows a purchaser to incorporate the cost into their mortgage, making it more affordable. For community facilities, consider using renewable energy infrastructure such as solar or geothermal to reduce energy costs and further reduce pollution created from offsite generation. Grant funds and incentives are available for Delmarva Power customers through the DNREC Green Energy Fund, which includes several funding types through the state's major electric utilities (https://dnrec.delaware.gov/climate-coastal-energy/renewable/assistance/).

- Consider planting select areas with native trees. Native trees improve air, water, and soil quality. Planting and nurturing trees is also a nature-based solution to reducing the greenhouse gases that drive climate change. In addition, native trees have an increasingly important role in the survival of native birds and beneficial insects whose habitat is shrinking due to development and climate change.

- Consider planting select areas with meadow comprised of native species. Native plants are well-suited to our climate and require limited maintenance. Mowing in these areas should not occur between April 1st to July 31st to reduce impacts to nesting birds and other wildlife species that utilize meadows and grasslands for breeding habitat.

- Use efficient Energy Star rated products and materials in construction and redevelopment. Energy efficient appliances use less energy over time. This saves consumers and businesses money, while also helping to reduce pollution from power generation.

- Use structural paint coatings that are low in Volatile Organic Compounds to help protect air quality. Air pollution from new construction is generated through the use of maintenance equipment, paints, and consumer products like roof coatings and primers.

- Use recycled materials, such as reclaimed asphalt pavement, to reduce heat island effects on paved surfaces, prevent landfill waste, and lower material costs.

Contact: DNREC Division of Climate, Coastal & Energy at (302) 735-3480.
Website: https://dnrec.delaware.gov/climate-coastal-energy/

Delaware State Fire Marshall's Office – Contact Duane Fox 302-739-4394
Preliminary meetings with fire protection specialists are encouraged prior to formal submittal. Please call for appointment. Applications and brochures can be downloaded from our website: www.statefiremarshal.delaware.gov, technical services link, plan review, applications or brochures.

Fire Department Comments:

- The fire department is obligated to provide fire and EMS service to this property. Additional new development within their fire/EMS district has put a financial strain on the volunteer fire service. In order to provide quality service within the fire/EMS district the fire department may have to hire career staff to keep up with the demand of service. Currently State and County funding is not keeping up with the growth of the fire district and the burdens placed on the volunteer fire department. The developer and future residents will need to consider financial support, before this becomes a tax burden. Volunteerism is dwindling so future residents need to consider joining the fire department to serve their new community.

Following receipt of this letter and upon filing an application with the local jurisdiction, the applicant shall provide to the local jurisdiction and the Office of State Planning Coordination a written response to comments received as a result of the pre-application process, noting whether comments were incorporated into the project design or not and the reason, therefore.

Thank you for the opportunity to review this project. If you have any questions, please contact me at 302-739-3090.

Sincerely,

David L. Edgell, AICP
Director, Office of State Planning Coordination